

To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kuteer, ITO, New Delhi

Part I

Dispatch No

AE-IT/C-9/DUSIB/2020/0-55

Date:

13/10/2020.

Sub: Testing of CC cubes of mix ---M-15 for 28 days Compressive Strength.

A. L. No. -

15/LOA/EE/C-9/DUSIB/2019/18/D-525

Dated:

09/07/2020

Name of work:

TIA for exist up in infrastructure

Sub Head:

Const. of 10 wave with fence. raising of floor & allied works in wave shop at Gajpur

1. Details from where sample is collected
2. Name of Circle/Division
3. Name of Executive Engineer
4. Name of Assistant Engineer
5. Name of Junior Engineer
6. Name of Contractor/Agency
7. Name of Officer collecting sample
8. Date of collection:
9. Date of Testing
10. Quantity of sample sent for testing:
11. Required strength:
12. No. of specimen sent for testing:
13. Size of specimen:
14. Mark of specimen:

from site

3/C-9

Sh.P.K. Singh

Maharshadal

Veer Bahadur Meena

M/s Regional Btanti

Maharshadal

16/09/2020

14/10/2020

20103 C-9

as per CPWD specifications

03 Nos.

15cm X 15cm X 15cm

RPB

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked A has/have been taken in my presence, which represent 20 cum quantity of works/supply made at site/store.

Signature of AE

In charge of work

Signature of Contractor

Signature of Officer

taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2019/18/D-500

Test No. 421

Date: 14/10/2020

Date of Receipt: 14.10.2020

Date of testing: 14.10.2020

Concrete Mix:

M-15

Date: 14.10.2020

CPWD specifications

15 Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq. cm. mm ²	Compressive Strength		Average Strength (Kg/sq. cm) N/mm ²	Remarks
			Load (Tonnes)	Comp. strength (Kg/sq. cm) N/mm ²		
1.	8600gm	2250	433	19.24	19.47 N/mm ²	Correlate Accordingly
2.	8560gm	2250	438	19.47		
3.	8590gm	2250	439	19.51		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)

DUSIB Vikas Kuteer, ITO

Quality Control Lab., Vikas Kuteer, ITO, New Delhi

Attn: Mr. A.C.T. of DUSIB

(K-9) New Delhi-110002

Copy to:-

1. EE/C-9
2. qc