

The Assistant Engineer (QC)
Quality-Control Lab, DUSIB
Vikas Kuteer. ITO, New Delhi

207

PWD-1841

25 FEB 2019

Part I

No. 72/AE-III/C-2/DUSIB

Date: 25/2/19

Sub: Testing of CC cubes of mix 1:1.5:3 for 7/28 days Compressive Strength.

AL.No.: WF/4766/21/AE-III/C-2/2017-18/D-812 Dated:-28.03.2018

1. Name of work: Imp. of SC/ST/ OBC Minorities Basties.

Sub Head:- Construction of Julaha Chaupal (3-Storeyed) at Village Mundka , AC-8,
Mundka.(Project ID -10099)

2. Details from where sample is collected: From Site.....
3. Name of Circle/ Division: ...C-2.....
4. Name of Junior Engineer: Sh. Ravinder Kumar
5. Name of Assistant Engineer: Sh. P.S. Johar
6. Name of Executive Engineer: Sh. Kamal Singh
7. Name of Contractor / Agency: M/S Vashishth Associates.
8. Name of Officer Collecting Sample: Sh.P.S. Johar
9. Date of collection : ...28-01-2019...
10. Date of testing: ...25-02-2019.....
11. Required Strength: Mix.1:1.5:3
12. No. of specimen sent for testing: 3 Nos. Cube
13 Size of specimen: 15x15x15 cm.
14.Mark of specimen:

Specimen relating to work mentioned above is / are sent for testing. It is
certified that the sample (s) marked Spn. has / have been taken in my presence which
represent quantity of work / supply made at site / store.

Signature of J.E.

Signature of Contractor

Signature of Officer
Taking sample (P.S. Johar)

Part II

No. SE(QC)/AE(Lab)/2018/D-2399

Test No. 1895 Date: 25.2.19

Date of Testing: 25.2.19

Concrete Mix 1:1.5:3

Date: 25/2/19
Date of Receipt: 25.2.19

Day Test: 28 days

S. No	Wt. of specimen (In gms.)	Area (In Sq. cm.)	Compressive Strength		Average Strength (In Kg/sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (In Kg/sq.cm)		
1.	8490 gm	225	61.50 T	273.33	274.61 Kg/cm ²	ACCEPTABLE
2.	8441 v	225	60.0 T	266.67		
3.	8523 *	225	64.0 T	284.44		

Tested in my presence

Only testing has been conducted in this laboratory, the sample have been
collected, cured and handed over by the field staff of the concerned division.

copy to:
1. EE/C-2
2. O/C

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kuteer, ITO.
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-110002