To,

The Assistant Engineer (QC) Quality Control Lab, DUSIB Vikas Kutir, ITO, New Delhi

3743

RNO. 598

Part I

No.. M.T. JA.C .. 39/AE - 1/c-10/2018-19/D-140

Date: 10.8'2018

Sub: Testing of Bricks/Bricks tiles for Water Absorption/Efflorescence.

w.o.	No.:- WB/4321/PG/EEC-10/DUSIB/18-	19 /D- 251 Dated: 30.06.2018
1.	N.O.W: C/O Shishu Vatika (Capital)	
	Sub Head: Construction of shishu Vatil	ka at JJ Bastie, Block-C, Rajiv Gandhi Camp, Naraina
	Vihar in AC-39 (Project ID 000010255	())
2.	Detail from where sample is collected:	Site
3.	Name of Circle/Division:	. Circle-4, C-10
4.	Name of Junior Engineer:	N/A
5.	Name of Assistant Engineer:	Ashwani Kumar
6.	Name of Executive Engineer:	Sh. Shyam Singh
7.	Name of Contractor/Agency:	Ms/ Nanak Chand
8.	Name of Officer collecting sample:	Ashwani Kumar
10.	Date of collection/Date of filling frog:	8.08.2018
11.	Date of Testing:	13.08.2018
12.	Identification Mark:	MV-P
13.	Class designation:	7.5
14.	No. of specimen sent for testing:	10

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked... MVD ... has/have been taken in my presence which represent... Ha, OUR quantity of work/supply made at site/store.

Noual Chaml Signature of Contractor

Signature of Officer taking sample (EE/AE)

## Part II

## TEST REPORT

No. SE (QC)/AE (Lab)/2011/D-739 Date: 03/09/18
Test No. 598 Date 13.8,18

Date of Receipt

eceipt 13|8|18

Date of Testing

(A) WATER ABSORPTION

My Day West of Absorption

Day of Testing upto 31.8.18
sorbed (gms) %age water Average

S. No.	Dry Wt. (gms)	Wet Wt.(gms)	Water Absorbed (gms)	%age water Abosrbed	Average absorption water
1. 2. 3. 4. 5.	3217 3282 3257 3270 3240	3624 3734 3685 3681 3684	14411	13.77	13-54%

(B) EFFLORESCENCE

Dt. Of testing upto: 31/8/18

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

Copy to: Assistant Engineer (QC) Lab.

13. .....

DUSIB, Vikas Kutir, ITO