

To

The Assistant Engineer(QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

4674

PND 1423

09 JAN 2019

**Part I**Dispatch No. D-129/ACI/C-8/DUSIB/2018Date: 09/11/19

Sub: Testing of CC cubes of mix M-35 for 7/28 days Compressive Strength.

A. L. No- 17/EE/C-8/DUSIB/2018-19/D-465

Dated-04-08-2018

## 1. Name of work: EIUS

SH: P/L cement concrete pavement and C/O drain in SC/ST Basti Ward 262, E.B.7-1(C.N. 882 to 955),  
E.B.4-1(C.N. 441 to 514) Block-A, Amar Colony, Gokalpur(AC-68).(Project ID 000010604)

## 2. Details from where sample is collected

at site

## 3. Name of Circle/Division:

C-III/C-8

## 4. Name of Junior Engineer:

Sh A.K. Bhaskar

## 5. Name of Assistant Engineer:

Sh Anil Kumar

## 6. Name of Executive Engineer:

Sh. K.B.Sharma

## 7. Name of Contractor/Agency:

Sh.Y.K GOYAL

## 8. Name of Officer collecting sample:

Sh. Anil Kumar

## 9. Date of collection:

09/12/2018

## 10. Date of testing:

09/01/2019

## 11. Required strength:

As per CPWD Specification

## 12. No. of specimen sent for testing:

-- 3 nos.

## 13. Size of specimen:

15 X 15 X 15 cm

## 14. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/  
samples marked 78 has/have been taken in my presence which represent 50% quantity  
of works/supply made at site/store.

Signature of JE  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

**Part II****TEST REPORT**

No. SE(QC)/AE(Lab)/2018-19/D-1665

Date: 09/11/19Test No. 1423 Date: 01.1.19Date of Receipt: 09/11/19

Date of testing:

Concrete Mix: M-35Days test: 3 days

S. No	Wt. of specimen in gms	Area in sq.cm. mm <sup>2</sup>	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes) <sup>KN</sup>	Comp. strength (Kg./sq.cm)		
1.	8623 gm	2250	685	30.44	30.50 N/mm <sup>2</sup>	EE May Correlate Accordingly
2.	8606 "	2250	691	30.71		
3.	8569 "	2250	683	30.36		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and  
handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)  
DUSIB, Vikas Kutir, ITO  
Assistant Engineer (QC)  
Delhi Urban Shelter Improvement Board  
Gov. of C.T. of Delhi  
ITO, New Delhi-02

Copy to:-

1. EE/C-8  
2. 9c