

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

4349

PNO-1133

28 NOV 2018

Part I

Dispatch No. D-09/1AE/II/112/DUSIB/2018 Date: 26/11/2018

Sub: Testing of CC cubes of mix M-30 for 28 days Compressive Strength.

AL No. 07/WK/7205(201)/EEC-12/DUSIB/2018-19/D-808 dated 05.10.2018

NOW: Imp. of SC/ST Basties NCTD. SH: P/L RMC with paver tiles, central verge on 15.00 mtr. Main market road for block-B and D and imp. of drainage system including covering of drain and RMC on 9.00mtr. road in block-D at Shahbad Daulatpur (Sahba (Project ID 000010971)).

- | | | |
|----|--|-----------------------|
| 1 | Details from where sample is collected | ----- |
| 2 | Name of Circle/Division | Circle-4/C-12 |
| 3 | Name of Junior Engineer | N.N. Singh |
| 4 | Name of Assistant Engineer | Satish Chandra |
| 5 | Name of Executive Engineer | Sh. Arun Kumar |
| 6 | Name of Contractor/Agency | M/S Ansul Builders |
| 7 | Name of Officer collecting sample | <u>Satish Chandra</u> |
| 8 | Date of collection: | 30-10-2018 |
| 9 | Date of testing: | 26-11-2018 |
| 10 | Required strength: | ----- |
| 11 | No. of specimen sent for testing: | 03 Nos. |
| 12 | Size of specimen: | 15x15x15 |
| 13 | Mark of specimen: | R |

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked---R-----has/have been taken in my presence which represent--36---quantity of works/supply made at site/store.

N.N.S.

Signature of JE
In charge of work

Satish
Signature of Contractor

Satish 26/11/18
Signature of Officer
taking sample (EE/AE)

Part II**TEST REPORT**

No. SE(QC)/AE(Lab.)/2018/D- 13391

Date: 03/12/18

Test No. 1133 Date: 28.11.18

Date of Receipt: 28.11.18

Date of testing: 28.11.18

Concrete Mix: M-30

M-30

Days test: 29 days

S. No	Wt. of specimen in gms	Area in sq. cm. mm ²	Compressive Strength		Average Strength (Kg./sq. cm) N/mm ²	Remarks
			Load KN (Tonnes)	Comp. strength (Kg./sq. cm) N/mm ²		
1.	8510 gm	2250	750	33.33	34.01 N/mm ²	EE May Correlate Accordingly
2.	8488 "	2250	769	34.18		
3.	8566 "	2250	777	34.53		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Copy to:-

- EE/C-12
- O/C

Satish 28/11/18
Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T., of Delhi
ITO, New Delhi-02