

3748

Part I
No. D-117/AE-VII/C-2/DUSIB

Date: 29/8/18

Sub: Testing of CC cubes of mix M-25 for 28 days Compressive Strength.

PID = 3271

1. Name of work :- N.O.W :- Construction of 7620 (G+4) EWS Low Cost Houses For Slum Dwellers (Under JNNURM) at Savdā Ghewra Phase-III, SH:- Construction of (Double Storied) Composite Centre / Community Hall at Site No-III at Savda Ghewra Ph-III
2. Details from where sample is collected: ... From site.....
3. Name of Circle / Division: ... Circle-I/ C-2.....
4. Name of Junior Engineer:NA.....
5. Name of Assistant Engineer: ... Sh. J.N. Garg...
6. Name of Executive Engineer: ... Sh. S.C. Sharma.....
7. Name of Contractor / Agency: ... **M/s D R BUILDERS**
8. Name of Officer Collecting Sample: ... Sh. J.N. Garg ...
9. Date of collection : ... 11/8/18
10. Date of testing: ... 29/8/18
11. Required Strength: ... KG/SQCM.....
12. No. of specimen sent for testing:3.....
13. Size of specimen: ... 150x150x150 mm...
A, B, C
14. Mark of specimen

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked ...A,B,C... has / have been taken in my presence which represent 20 cum quantity of work / supply made at site / store.

Signature of Contractor

Signature of Officer

Taking sample (EE / AE)

Part II

No. SE(QC)/AE(Lab)/2017-18/D-749

Test No. 144 Date 29.8.18

Date of Testing: 29.8.18

Concrete Mix M:25

Date: 02/09/18

Date of Receipt: 29.8.18

Day Test: 28 days

S. No	Wt of specimen (In gms.)	Area (In Sq cm) mm ²	Compressive Strength		Average Strength (In Kg/sq.cm)	Remarks
			Load KN (Tonnes)	Comp. strength N/mm ² (In Kg/sq.cm)		
1.	8494g	22500	658 KN	29.24	29.55 N/mm ²	EE May Correlate Accordingly
2.	8525	22500	666 "	29.60		
3.	8560 "	22500	671 "	29.82		

Tested in my presence

Only testing has been conducted in this laboratory, the sample has been collected, cured and handed over by the field staff of the concerned division.

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kuteer, ITO.

29/8/18

[Handwritten Signature]

COPY TO:-
1 EE/C-2

2. %