

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
VikasKutir, ITO, New Delhi

RNo. 601

13 AUG 2018

Part I

No:- WG/4865/AE -IV/C-3/18-19/D- 5

Date: 13.8.18

Award latter no. : WG/4814(14)/EEC-3/DUSIB/18-19/D-680

Dated 25-07-2018

Sub: Testing of Bricks/~~Bricks~~ for Water Absorption/Efflorescence.

1. NOW :- GIA
2. SH :- Closing of four no. Gates & providing boundary wall, gates, grills and marble wash at missing places for the ground (Ram leela maidan), situated adjacent to kala mandir cinema and opposite community hall at A,B,C block Mangolpuri (project ID10562)
3. Detail from where sample is collected Above noted work.
3. Name of Circle/Division: Circle-I, C-3
4. Name of Junior Engineer Sh. Anuj
5. Name of Assistant Engineer: Sh. R.C. Goel
6. Name of Executive Engineer: Sh. V.S. Fonia
7. Name of Contractor/Agency: M/s Nanak Chand
8. Name of Officer collection sample : Sh. R.C. Goel
9. Date of collection/~~Date of filling frog~~: 08/8/18
10. Date of Testing: 13/8/18
11. Identification Mark: mvd
12. Class designation: 75 kg/cm²
13. No. of specimen sent for testing: 10

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked....~~mvd~~... has/have been taken in my presence which represent..... quantity of work/supply made at site/store.

Signature of JE
Incharge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II TEST REPORT

No. SE (QC)/AE (Lab)/2004/D- 736

Date: 03/09/18

Test No. 601

Date 13-8-18

Date of Receipt 13/8/18

Date of Testing 13.8.18

(A) WATER ABSORPTION Day of Testing upto

mvd

→ 21.8.18

S.No.	Dry Wt. (gms)	Wet Wt.(gms)	Water Absorbed (gms)	%age water Absorbed	Average absorption water
	3190	3609	419	13.13	13.08%
	3257	3685	428	13.35	
	3136	3564	428	13.65	
	3242	3670	428	13.03	
	3143	3584	341	12.25	

(B) EFFLORESCENCE

Shykh

Dt. Of testing upto: 31/8/18

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

Copy to:

1. ...EE... 3
2. ...0/1

Assistant Engineer (QC) Lab.
DUSIB, VikasKutir, ITO