

**DELHI URBAN SHELTER IMPROVEMENT BOARD  
GOVT. OF NCT OF DELHI**

To

The Assistant Engineer (QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

R.NO. 0553 Project ID . 05794

RECEIVED 05 JUN 2017

**Part I**

Dispatch No

D-39/AE/08/DUSIB/2017

Date:

05/06/2017

**Sub: Testing of CC cubes of mix M-25 for 7/28 days Compressive Strength.**

A. L. No. 40/EE/08/DUSIB/16-17/D-782

Dated. 22/11/2016

1. Name of work: JSC (Layam)  
SH: C/O JSC in JSC Tami Mandir Block B-1/35 Birla Garden Col. Post above Plover beam
2. Details from where sample is collected: C-III/08
3. Name of Circle/Division: Sh. Bal Singh
4. Name of Junior Engineer: Sh. Rakish Kumar
5. Name of Assistant Engineer: Sh. P. K. Garg
6. Name of Executive Engineer: M/S. A. K. G. Gang.
7. Name of Contractor/Agency: Sh. Rakish Kumar A/S
8. Name of Officer collecting sample: 8-5-2017
9. Date of collection: 5-6-2017
10. Date of testing: M-25
11. Required strength: Three
12. No. of specimen sent for testing: 15x15x15cm
13. Size of specimen: R.K.
14. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked R.K. has/have been taken in my presence which represent 8.20m<sup>3</sup> quantity of works/supply made at site/store.

Signature of JE

Signature of Contractor

Signature of Officer taking sample (BE/AE)

**Part II**

**TEST REPORT**

No. SE(QC)/AE(Lab.)/2017-12/D-

Test No. 0553 Date: 5.6.17

Date:

Date of Receipt: 5.6.17

Date of testing: 5.6.17

Concrete Mix: M-25

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8434	225	6800	302.22	291.1	EE May Correlate Accordingly
2.	8417	225	6400	284.44		
3.	8368	225	6500	288.89		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)  
DUSIB, Vikas Kutir, ITO  
Delhi Urban Shelter Improvement Board  
Govt. of N.C.T. of Delhi  
ITO, New Delhi-02

Copy to:-

1. EBC-8
2. dlc