

Part I

No D-438/AE-I/EEC-03/DUSIB/2018-19

R.No. 1652

30 AUG 2018

Date: 30/08/18

Sub: Testing of CC cubes of mix RMC M-25 for 28 days comp. strength

- 1 Name of Work:- Development of SC/ST Basties.
SH:- Imp. Of lanes by providing/ laying RMC and imp. Drainage system in lanes of Block F-2 Sultanpuri(AC-10) from H.No. F-2/241 to F-7/36).
P.I.D 6394

WO. No. WG/4814(09)/EEC-3/DUSIB/18-19 /D-577

Dated 20/06/2018

- 2 Detail from where sample is collected: Above noted work.
3 Name of Circle/Division: Circle-I, C-3
4 Name of Junior Engineer Sh. Yudhbir Malik
5 Name of Assistant Engineer: Sh. Dori Lal
6 Name of Executive Engineer: Sh. V.S.Fonia
7 Name of Contractor/Agency: M/S. Aarav Const. Co.
8 Name of Officer collection sample : Sh. Dori Lal
9 Date of collection: 02/08/18
10 Date of Testing: 30/08/18
11 Required Strength: As per specification
12 No. of specimen sent for testing: 3 Nos.
13 Size of specimen: 15X15X15 Cms.
14 Mark of Specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked..... has/have been taken in my presence which represent.. 30m³ quantity of work/supply made at site/store.

Signature of JE
Incharge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2018/D-754 Date: 03/09/18
Test No. 652 Date 30.8.18

Date of Receipt 30.8.18

Date of Testing 30.8.18

Concrete Mix M-25 Day test 28 days

S. No.	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength Kg/sq.cm	Remarks
			Load (Tonnes)	Comp.strength (Kg./sq.cm)		
1.	8710 gm	22500	648 kN.	28.80	28.73	EE May Correlate ACCEPTABLY
2.	8561 "	22500	638 "	28.36		
3.	8598 "	22500	653 "	29.02		

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

Copy to: EE/C-3

1. EE/C-3

2. O/C

Assistant Engineer (QC) Lab.

Assistant Engineer Vikas Kutir, ITO
Quality Control Lab, S & JJ, MCD