The Assistant Engineer (QC) Quality Control Lab, S & JJ, MCD Vikas Kutir, ITO, New Delhi

4258

0 6 NOV 2018

Part I

No D-499/AE-I/EEC-03/DUSIB/2018-19

Date: 03 11 18

Sub: Testing of CC cubes of mix RMC M-25 for 28 days camp, strength

Name of Work:- Development of SC/ST Basties. P.I.D 6394
SH:- Imp. Of lanes by providing/ laying RMC and imp. Drainage system in

lanes of Block F-2 Sultanpuri(AC-10) from H.No. F-2/241 to F-7/36.

WO. No. WG/4814(09)/EEC-3/DUSIB/18-19 /D-577 Dated 20/06/2018

2 Detail from where sample is collected: Above noted work.

Name of Circle/Division: Circle-I, C-3

4. Name of Junior Engineer Sh. Yudhbir Malik

Name of Assistant Engineer: Sh. Dori Lal
 Name of Executive Engineer: Sh. V.S.Fonia

7. Name of Contractor/Agency: M/S. Aarav Construction Company

8. Name of Officer collection sample: Sh. Dori Lal

9. Date of collection: 5 10 20 8 10. Date of Testing: 2 11 20 8

11. Required Strength: As per specification

12. No. of specimen sent for testing: 3 Nos.

Signature of JE Incharge of work

Signature of Contractor

Signature of Officer taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Latb)/2008/D- \250 Date: 06 | 11 | 18
Test No. \063 Date 6.11.18

Date of Receipt
Date of Testing

Concrete Mix 06.11.18 M. 25 Day test 32 days

Con	erete Mix	m.2	Day t	est 3:	Loloys			
S. No.	Wt. of specimen in gms	Area in sq.cm.	Compress	comp.strength (Kg./sq.cm)	Average Strength Kg/sq.cm	Remarks		
1.	8550 gm	22500	677	30.09			May	
2.	8579"	27500	686	30149	30,29	Corr	ele dingly	
3.	85980	Sys	688	30.58	N/mm2	Acco	4,1 9,1	

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

GOP Y TO :

| Gelhi Urban Shelier Improvement
| Gov. of N.C.T., of Delhi
| ITG. Now Delhi-02
| Assistant Engineer (OC) La