

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

1310

RNo. 1539

RECEIVED 08 OCT 2017

Part IDisp. Ch No R-148/AE-DII/C-11/DUSIB/2017Date: 06/10/17Sub: Testing of CC cubes of mix M-15 for 7/28 days Compressive Strength.A. L. No. FLWC/4450/AL-54/DEC-11/DUSIB/2016-17/1498Date: 14/3/20171. Name of work: EIUS

(Project Id 000007768)

SH: Imp. of drainage system and providing & laying CC pavement over existing deteriorated portion in JI cluster at W Block, Pitampura2. Details from where sample is collected From site3. Name of Circle/Division Circle-4 / C-11

4. Name of Junior Engineer

5. Name of Assistant Engineer

6. Name of Executive Engineer

7. Name of Contractor/Agency

8. Name of Officer collecting sample

9. Date of collection: 8/9/1710. Date of testing: 6/10/1711. Required strength: As per M-1512. No. of specimen sent for testing: 3 Nos13. Size of specimen: 150mm X 150mm X 150mm

14. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked-----has/have been taken in my presence which represent-----quantity of
works/supply made at site/store.

Signature of AE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II**TEST REPORT**

No. SE(QC)/AE(Lab.)/2017-18/D-

Test No. 1539 Date: 6/10/17Date of Receipt: 06/10/17Date of testing: 06/10/17Concrete Mix: M-15Date: 09/10/17Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8390 gm	225	44.07	195.56	187.41	TE May Correlate Accordingly
2.	8515 gm	225	41.07	182.22		
3.	8500 gm	225	41.507	184.44		

Tested in my presence [Signature]

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and
handed over by the field staff of the concerned division.

Copy to:-

1. EE/C-11
2. dc

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Development Board
Delhi-110002