

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R No - 1665
RECEIVED 24 OCT 2017

Part I

Dispatch No. AE/24 DUSIB/2017-18/D-212 Date: 24.10.17

Sub: Testing of CC cubes of mix M-25 for 28 days Compressive Strength.

AL No. 27/WK/7205(180)/EEC-12/DUSIB/2017-18/D-586 dated 24-07-2017.

NOW: SC/ST Basti SH: Repair/restoration by providing and laying RMC Pavement on road including covering and repairing of drain etc. in between block B and C at SRS Bawana.

(Project ID 000006750)

1	Details from where sample is collected	<u>Site</u>
2	Name of Circle/Division	Circle-IV/C-12
3	Name of Junior Engineer	
4	Name of Assistant Engineer	Rakesh Kumar
5	Name of Executive Engineer	Sh. Kamal Kumar <u>Signature</u>
6	Name of Contractor/Agency	M/s Rakesh Kumar Goel
7	Name of Officer collecting sample	Rakesh Kumar/Kamal Kumar <u>Signature</u>
8	Date of collection:	<u>26.9.17</u>
9	Date of testing:	<u>24.10.17</u>
10	Required strength:	<u>As Specified</u>
11	No. of specimen sent for testing:	03
12	Size of specimen:	15X15X15 cm
13	Mark of specimen:	<u>dr. m. 12</u>

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked-----has/have been taken in my presence which represent-----quantity of works/supply made at site/store.

Signature
Signature of JE
In charge of work

Signature
Signature of Contractor

Signature
Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2017-18/D- 1937

Date: 25/10/17

Test No. 1665 Date: 24.10.17

Date of Receipt: 24/10/2017

Date of testing: 24/10/2017

Concrete Mix: M-25

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8320gm	225	63.00 T	280.00	288.15 <u>legume</u>	EE May Correlate Accordingly
2.	8620gm	225	66.00 T	293.33		
3.	8555gm	225	65.50 T	291.11		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Signature
Assistant Engineer(QC-Lab)

DUSIB, Vikas Kutir, ITO
Delhi Urban Shelter Improvement Dept.