

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R.No: 1475

RECEIVED 22 SEP 2017

Part IDispatch No AGT/CTM DUSIB/2017-18/D-162 Date: 21.8.17Sub: Testing of CC cubes of mix M20 for 28 days Compressive Strength.

AL No. 09/WK/7205(154)/EEC-12/DUSIB/2017-18 /D- 412 dated 23-05-2017.

NOW: SC/ST Basti SH: Repair/restoration by providing and laying RMC Pavement on road including covering and repairing of drain etc. in between block A & B at SRS Bawana (Project ID 000006752)

- 1 Details from where sample is collected 8.2
- 2 Name of Circle/Division Circle-IV/C-12
- 3 Name of Junior Engineer -----
- 4 Name of Assistant Engineer Rakesh Kumar
- 5 Name of Executive Engineer Sh. Kamal Singh
- 6 Name of Contractor/Agency M/s Rakesh Kumar Goel
- 7 Name of Officer collecting sample Rakesh Kumar/Kamal Singh
- 8 Date of collection: 24.8.17
- 9 Date of testing: 21.8.17
- 10 Required strength: As per spec
- 11 No. of specimen sent for testing: 03
- 12 Size of specimen: 15X15X15 cm
- 13 Mark of specimen: 8.2

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked 8.2 has/have been taken in my presence which represent 4 quantity of works/supply made at site/store.

AE
Signature of AE
In charge of work

Contractor
Signature of Contractor

Officer
Signature of Officer
taking sample (EE/AE)

Part II**TEST REPORT**No. SE(QC)/AE(Lab.)/2017-18/D- 1727Date: 26/09/17Test No. 1475 Date: 22/09/17Date of Receipt: 22/8/2017Date of testing: 20/8/2017Concrete Mix: M-25Days test: 29 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8298 gm	225	65.0T	288.89	292.59 Kg/cm ² <u>EE May Correlate Accordingly</u>	
2.	8410 "	225	66.0T	293.33		
3.	8466 "	225	66.5T	295.56		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board

Copy to:-