

To,

The Assistant Engineer (QC)
Quality Control Lab, S & JJ, MCD
Vikas Kutir, ITO, New Delhi

3422

20 JUN 2018

Part I

No D-407/AE-I/EEC-03/DUSIB/2018-19

Date: 18.6.18

Sub: Testing of CC cubes of mix RMC M-25 for 28 days comp. strength

1. Name of Work:- Development of SC/ST Basties.
SH:- Imp. Of lanes by providing/ laying RMC and imp. Drainage system in lanes of Block P-2 Sultanpuri(AC-10) from H.No. P2/14 to P-2/365 Dhallo. P.I.D :- 6921

WO. No. WG/4814(02)/EEC-3/DUSIB/18-19 /D- 444 Dated 16-05-2018

- 2 Detail from where sample is collected: Above noted work.
3 Name of Circle/Division: Circle-I, C-3
4 Name of Junior Engineer Sh. Yudhbir Malik
5 Name of Assistant Engineer: Sh. Dori Lal
6 Name of Executive Engineer: Sh. V.S.Fonia
7 Name of Contractor/Agency: Sh. Fairdeal Const. Co.
8 Name of Officer collection sample : Sh. Dori Lal
9 Date of collection: 23-5-2018
10 Date of Testing: 20-6-2018
11 Required Strength: As per specification
12 No. of specimen sent for testing: 3 Nos.
13 Size of specimen: 15X15 Cms.
14 Mark of Specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked..... has/have been taken in my presence which represent 40m³ quantity of work/supply made at site/store.

Signature of JE
Incharge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2018/D- 426

Date: 20/06/18

Test No. 371

Date 20/06/18

Date of Receipt 20/6/18

Date of Testing 20/6/18

Concrete Mix

M-25

Day test

28 days

S. No.	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength Kg/sq.cm	Remarks
			Load (Tonnes)	Comp.strength (Kg/sq.cm)		
1.	8572 gm	2250	677	30.08	30.13 N/mm ²	EE May Correlate Accordingly
2.	8543 .	2250	674	29.96		
3.	8512 "	2250	683	30.36		

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

Copy to:

1. EE/C-3

2. o/c

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)