

To,

The Assistant Engineer (QC)
Quality Control Lab, S & JJ, MCD
Vikas Kutir, ITO, New Delhi

R.NO: 681

05 SEP 2018

3800

Part I

No D-445/AE-I/EEC-03/DUSIB/2018-19

Date: 5-9-18

Sub: Testing of CC cubes of mix RMC M-25 for 28 days comp. strength

- 1 Name of Work:- Development of SC/ST Basties. P.I.D 6922
SH:- Imp. Of lanes by providing/ laying RMC and imp. Drainage system in lanes of Block P-2 Sultanpuri(AC-10) from H.No. P2/11 (Govt. School) to P-2/286 Dhallo
WO. No. WG/4814(05)/EEC-3/DUSIB/18-19 /D-467 Dated 19/05/2018
- 2 Detail from where sample is collected: Above noted work.
3. Name of Circle/Division: Circle-I, C-3
4. Name of Junior Engineer Sh. Yudhbir Malik
5. Name of Assistant Engineer: Sh. Dori Lal
6. Name of Executive Engineer: Sh. V.S.Fonia
7. Name of Contractor/Agency: M/S. Naresh Kumar Gupta
8. Name of Officer collection sample : Sh. Dori Lal
9. Date of collection:6-8-18.....
10. Date of Testing:5-9-18.....
11. Required Strength: As per specification
12. No. of specimen sent for testing: 3 Nos.
13. Size of specimen: 15X15X15 Cms.
14. Mark of Specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked..... has/have been taken in my presence which represent..... quantity of work/supply made at site/store.

Signature of JE
Incharge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part IITEST REPORT

No. SE (QC)/AE (Lab)/2018 D-796 Date: 06/09/18

Test No. 681 Date 05.09.18

Date of Receipt 05.9.18

Date of Testing 05.9.18

Concrete Mix M25

Day test 30 days

S. No.	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength	Remarks
			Load (Tonnes)	Comp.strength (Kg/sq.cm)		
1.	8702 gm	2250	KN 724	N/mm ² 32.18	N/mm ²	EE May Correlate Accordingly
2.	8588 "	2250	699	31.07	31.81	
3.	8593 "	2250	696	30.67	N/mm ²	

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

Signature of Assistant Engineer (QC) Lab