

To,

The Assistant Engineer (QC)  
Quality Control Lab, S & JJ, MCD  
Vikas Kutir, ITO, New Delhi

R.NO: 1423

RECEIVED 18 SEP 2017

Part I

No. D-866/EEC-3/2017 Date: 18-9-17

Sub: Testing of CC cubes of mix RMC M-20 for 28 days comp, strength

1 NOW :- EIUS

SH :- Construction / Repair and covering of drains and P/L RMC in the deteriorated Lanes of J.J. Basti HRMR Bhatta Jwalapuri.

2. Detail from where sample is collected: Above noted work.
3. Name of Circle/Division: Circle-I, C-3
4. Name of Junior Engineer Sh. Raman Bhatt
5. Name of Assistant Engineer: Sh. V.k. Chauhan
6. Name of Executive Engineer: Sh. V.S. Fonia
7. Name of Contractor/Agency: M/s Manni Mahesh
8. Name of Officer collection sample : V.S. Fonia
9. Date of collection: 21-8-2017
10. Date of Testing: 18-9-2017
11. Required Strength: As per specification
12. No. of specimen sent for testing: 3 Nos.
13. Size of specimen: 15X15 Cms.
14. Mark of Specimen: Signature of AE/IE/EE/Agency

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked..... has/have been taken in my presence which represent..... quantity of work/supply made at site/store.

Signature of JE  
Incharge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2007/D- 1659 Date: 18/09/17  
Test No. 1423 Date  
Date of Receipt 18/9/2017  
Date of Testing 18/9/2017  
Concrete Mix M-20 Day test 28 days

S. No.	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength Load (Tonnes)	Comp.strength (Kg./sq.cm)	Average Strength Kg/sq.cm	Remarks
1.	8298 gm	225	51.50 T	228.89	235.56 kg/cm <sup>2</sup>	EE May Correlate Accordingly
2.	8336 "	225	53.50 T	237.28		
3.	8470 "	225	54.00 T	240.00		

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.