

To,

The Assistant Engineer (QC)
Quality Control Lab, S & JJ, MCD
Vikas Kutir, ITO, New Delhi

R.NO: 1438

RECEIVED 19 SEP 2017

Part I

No. D-865/EEC-3/2017

Date: 18.9.17

Sub: Testing of CC cubes of mix RMC M-20 for 28 days comp, strength

1 NOW :- EIUS

SH :- Construction / Repair and covering of drains and P/L RMC in the deteriorated Lanes of J.J. Basti HRMR Bhatta Jwalapuri.

2. Detail from where sample is collected: Above noted work.
3. Name of Circle/Division: Circle-I, C-3
4. Name of Junior Engineer: Sh. Raman Bhatt
5. Name of Assistant Engineer: Sh. V.k. Chauhan
6. Name of Executive Engineer: Sh. V.S. Fonia
7. Name of Contractor/Agency: M/s Manni Mahesh
8. Name of Officer collection sample : Sh. V.S. FONIA
9. Date of collection: 22.8.2017
10. Date of Testing: 19.9.17
11. Required Strength: As per specification
12. No. of specimen sent for testing: 3 Nos.
13. Size of specimen: 15X15 Cms.
14. Mark of Specimen: Signature of AE/IE/EE Agency

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked..... has/have been taken in my presence which represent..... quantity of work/supply made at site/store.

Signature of JE
Incharge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2007/D-167)

Date: 20/09/17

Test No. 1438 Date

Date of Receipt 19/9/2017

Date of Testing 19/9/2017

Concrete Mix

Day test

m-20

28 days

S. No.	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength Load (Tonnes)	Comp. strength (Kg./sq.cm)	Average Strength Kg/sq.cm	Remarks
1.	8400gms	225	53.07	235.56	238.26 kg/cm ²	EE May Corrostate Accordingly
2.	8468	225	54.507	242.22		
3.	8506	225	54.07	240.00		

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.