To,

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer, ITO, New Delhi

RNO. 1411
RECEIVED 15 SEP 2017

Part I
No......D-846, EE, C-3/2017   **Date:** 14.9.17

Sub: Testing of Bricks/Bricks tiles for Dimension/Compressive Strength.

1 NOW :- Poya use. J.S.C..........................

SH :Pdg. civil infrastructure for 90 seats prefab J.S.C. at JJ Basti Bheem Nagar behind Hari Nagar Bus Depot.

2.	**Detail from where sample is collected:**	Above noted work.
3.	**Name of Circle/Division:**	Circle-I, C-3
4.	**Name of Junior Engineer**	Sh. Raman Bhatt
5.	**Name of Assistant Engineer:**	Sh. V.k. Chauhan
6.	**Name of Executive Engineer:**	Sh. V.S. Fonia
7.	**Name of Contractor/Agency:**	M/s Ajay Enterprises
8.	**Name of Officer collection sample :**	...11-9-17 / 11-9-17...
9.	**Date of collection/Date of filling frog**	....11-9-17 /............
10.	**Date of Testing:**	.......15-9-17...............
11.	**Identification Mark:**	(KHATRI)...Sign of JE/AE/Agency
12.	**Class designation:**	7.5
13.	**No. of specimen sent for testing:**	20

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked............. has/have been taken in my presence which represent........... quantity of work/supply made at site/store.

Signature of JE
Incharge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II
No. SE (QC)/AE (Lab)/2017/D- 1649
Test No. 1411   Date 15.9.17   Date : 18/09/17
Date of Receipt 15/9/2017
Date of Testing 15/9/2017

Khatri

S. No.	Dimensions Length ~~Area~~ (cms) ~~(sq.cm)~~	Width (cms)	Maximum Strength Failure (T) Area	(max Load)	Compressive Strength failure (kg/sq.cm)	Average Compressive Strength ka/sq.cm
1.	21.90	10.50	229.95	22.00 T	95.67	ACCEPTABLE
2.	22.00	10.70	235.40	24.00 T	101.95/100	96.00 kg/cm²
3.	22.00	11.00	242.00	21.50 T	88.84	
4.	22.10	10.90	240.89	23.00 T	95.48	
5.	21.80	11.00	239.80	25.00 T	104.25	

DEMENSION TEST; FOR 20 BRICKS
1. **Length** : 4425 mm
2. **Width** : 2182 mm
3. **Height** : 1448 mm

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

Copy to:
1. EE/C-3
2. ....

15/9/17
Assistant Engineer (QC) Lab.
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board