R. No: 1679

RECEIVED 25 OCT 2017

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

Part I

Dispatch No D-90/AE-III/EEC4/DUSIB/2017 Date: 25-10-17

Sub: Testing of CC cubes of mix M-20 **for 7/28 days Compressive Strength.**

A. L. No. AL-33/WD/4-541/372/39/AE IV/EEC4/DUSIB/17-18/D-339 Dt 13-07-2017 Date:

1. Name of work:- Environmental Improvement in Urban Slums
   SH: Raising of lanes by providing and laying cc pavement and Improvement of drainage system in proposed Adarsh J.J. Basti at Rajiv Gandhi Camp, Road No. 77, Punjabi Bagh
2. Details from where sample is collected From the above said site [Project ID 000007337
3. Name of Circle/Division Circle-II/C-4
4. Name of Junior Engineer Sh. Yashvir Singh
5. Name of Assistant Engineer Sh. Anil Kumar Aggarwal
6. Name of Executive Engineer M/s. Yogesh Tyagi
7. Name of Contractor/Agency Sh. Yashvir Singh
8. Name of Officer collecting sample 27-9-17
9. Date of collection: 25-10-17
10. Date of testing: As per M-20
11. Required strength: 3 Nos
12. No. of specimen sent for testing: 15x15x15 cm
13. Size of specimen: No, Dt & sign
14. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample samples marked No, Dt & sign has/have been taken in my presence which represent 50 cum quantity of works/supply made at site/store.

Yogesh

25/10/17

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer taking sample (EE AE

Part II **TEST REPORT**

No. SE(QC)/AE(Lab.)/2017-18/D- 1949 Date: 25/10/17

Test No. 1679 Date: 25.10.17

Date of Receipt: 25/10/2017

Date of testing: 25/10/2017 Days test: 28 days

Concrete Mix: M-20

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength Load (Tonnes)	Compressive Strength Comp. strength (Kg./sq.cm)	Average Strength (Kg./sq.cm)	Remarks
1.	8306 gm	225	52.00 T	231.11	237.78	
2.	8410 "	225	54.00 T	240.00		
3.	8350 "	225	54.50 T	242.22		

DE May Correlate Accordingly

Yogesh

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

25/x/17

Assistant Engineer (QC)
DUSIB, Vikas Kutir

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02

COPY TO:-
+ EE/C-4