

To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

RNO. 927

RECEIVED 28 JUL 2017

Part I

Dispatch No. D-619EE C-12 / DUSIB /2017-18

Date: 28/7/17

Sub: Testing of Bricks/Brick tiles for Water Absorption / Efflorescence

A. L. No. 32/WK/7205(126)/EEC-12/DUSIB/2015-16/D-940 Date:04/11/2016

Name of Work: Pay and Use JSC.

Sub Head: Construction of 34 seater JSC in J.J. Cluster opposite BG-6 Paschim vihar (sonia camp). (ID no.7509)

1. Details from where sample is collected
2. Name of Circle/Division:
3. Name of Junior Engineer:
4. Name of Assistant Engineer:
5. Name of Executive Engineer:
6. Name of Contractor/Agency:
7. Name of Officer collecting sample:
8. Date of collection/Date of filling frog:
9. Date of testing:
10. Identification Mark:
11. Class designation:
12. No. of specimen sent for testing:

From site of work.

SE-IV/ Div./C-12

- N.A.-

Sh. A.K. Sardana

Sh. Kamal Singh

Sh. Sushil Kumar Jain

A.K. Sardana

28/7/17

28/7/17

CD-100

5

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked-----has/have been taken in my presence which represent-----quantity
of works/supply made at site/store.

Signature of JE

Incharge of work

Signature of Contractor

Signature of Officer
taking sample (JE/AE)**Part II****TEST REPORT**

No. SE (QC)/AE (Lab.)/2016-17/D- 1171

Date: 16/08/17

Test No. 927 Date: 28/7/17

Date of Receipt: 28/7/17

Date of testing up to:

(A) WATER ABSORPTION

S. No	Dry. Wt. (gms)	Wet. Wt (gms)	Water Absorbed (gms)	% age water absorbed	Average water absorption
1.	1337	1497	160	11.97	12.20 % ACCEPTABLE
2.	1468	1635	167	11.38	
3.	1451	1633	182	12.54	
4.	1441	1612	171	11.87	
5.	1404	1590	186	13.25	

(B) EFFLORESCENCE:

Efflorescence found: Nil / Slight / Moderate / Heavy

ACCEPTABLE

Date of testing up to:

16/8/2017

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and
handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)

DUSIB, Vikas Kutir, ITO

Delhi Urban Shelter Improvement Board

Govt. of N.C.T. of Delhi

ITO, New Delhi-110022

Copy to:-