

To,

The Assistant Engineer (QC)
Quality Control Lab, S & JJ, MCD
Vikas Kutir, ITO, New Delhi

RNO. 1451
RECEIVED 20 SEP 2017

Part I

No. 21274/ASE/10/10/2017

Date: 19-9-17

Sub: Testing of CC cubes of mix M-25 for 7/28 days comp, strength

Name of work:- Pay and Use JSC

Sub Head :- providing & laying CC pavement in approach road between JJ Clusters of Lal Bagh, Azadpur area & improvement of drainage system. (Project ID 000007590)

Acceptance Letter No.-WI/6031/08/PG/EEC-7/2017-18/D-491 date: 01/05/2017

2. Detail from where sample is collected: Above noted work.
3. Name of Circle/Division: Circle-III, C-7
4. Name of Junior Engineer: Sh. Tarun gaur
5. Name of Assistant Engineer: Sh. R.D Passi
6. Name of Executive Engineer: Sh K.B. sharma.
7. Name of Contractor/Agency: m/s- Manni Mahesh & Co.
8. Name of Officer Collection sample: Sh.R.D .Passi.
9. Date of collection: 23/8/17
10. Date of Testing: 20/9/17
11. Required Strength: M-25
12. No. of specimen sent for testing: 3 Nos.
13. Size of specimen: 15x15x15 Cms.
14. Mark of Specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked..... has/have been taken in my presence which represent 125 M³ quantity of work/supply made at site/store.

Signature of JE
In-charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2017/D-1699

Date 20.9.17

Date : 22/09/17

Test No. 1451

Date of Receipt : 20/9/17

Date of Testing : 20/9/17

Concrete Mix : M-25

Day test : 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength Kg/sq.cm	Remarks
			Load (Tonnes)	Comp.strength (Kg./sq.cm)		
1.	8505 gm	225	65.07	288.89	283.70	EE May Correlate Accordingly
2.	8480 "	225	63.07	280.00		
3.	8410 "	225	63.50	282.22		

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to :

EE/C-7

dlc

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02