

To,

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer, ITO, New Delhi

RNO. 861

RECEIVED 20 JUL 2017

Part I

No. 212401/AST/11/C-7/2017

Date: 19/7/17

Sub: Testing of Bricks/Bricks tiles for Dimension/Compressive Strength.

1. Name of work: -Pay & Use JSC

Sub Head: - Construction of 40 seater JSC at JJ cluster Cigrate wala Bagh Near hanuman mandir (Project ID 0000007653)

Acceptance No. WI/6031/108/PG/EEC-7/2016-17/D-226

DATE:-17/02/2017

- 2 Detail from where sample is collected: at site.
3. Name of Circle/Division: Circle-III, C-7
4. Name of Junior Engineer Sh. TARUN GAUR
5. Name of Assistant Engineer: Sh.R.D.PASSI
6. Name of Executive Engineer: Sh .K.B.SHARMA
7. Name of Contractor/Agency: M/s- Y.K.Goyal
8. Name of Officer collection sample : Sh. R.D.PASSI
9. Date of collection/Date of filling frog 15/7/17.....16/7/17.....
10. Date of Testing: 20/7/17.....
11. Identification Mark: ANTIL.....
12. Class designation: 7.5
13. No. of specimen sent for testing: 05 Nos.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked ANTIL has/have been taken in my presence which represent 100% quantity of work/supply made at site/store.

Signature of JE
In-charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2017/D- 1000

Date : 20/07/17

Test No. 861 Date 20.7.17

Date of Receipt 20.7.17

Date of Testing 20.7.17

S. No.	Dimensions			Maximum Strength Failure (T)	Compressive Strength failure (kg/sq.cm)	Average Compressive Strength kg/sq.cm
	Length (cms)	Width (cms)	Area (sq.cm)			
1.	22.00	11.40	250.80	26.00	103.66/100.00	9627 ACCEPTABLE
2.	22.00	11.00	242.00	23.00	95.04	
3.	21.70	11.00	238.70	21.00	87.98	
4.	22.00	11.00	242.00	24.00	99.17	
5.	22.00	11.00	242.00	24.00	99.17	

DEMENSION TEST: FOR 20 BRICKS

1. Length : — NOT ASKED FOR —
2. Width : —
3. Height : —

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to:

1. B.B./C-7
2.

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kutir, ITO