

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

RNO. 66/
RECEIVED 20 JUN 2017

Part I

Dispatch No.

D-III/AE-III/C-11/DUSIB/2017-18

Date:

19/06/2017

Sub: Testing of CC cubes of mix R.M.C. M.15 for 7/28 days Compressive Strength.

A. L. No.

F/WC/4450/AL-53/Com/EE-C-11/DUSIB/16-17/D-492

Date:

10.3.17.

1. Name of work:-

SH: - P/L C.C. pavements over existing deteriorated left out portion of 2% drains in JJ cluster near Ayurvedic Hospital, Hauz Khas (PID: 000007784).

2. Details from where sample is collected

From the site.

3. Name of Circle/Division

Circle-4 / C-11

4. Name of Junior Engineer

5. Name of Assistant Engineer

6. Name of Executive Engineer

7. Name of Contractor/Agency

8. Name of Officer collecting sample

9. Date of collection:

10. Date of testing:

11. Required strength:

12. No. of specimen sent for testing:

13. Size of specimen:

14. Mark of specimen:

Sh. S.K. Bhatia

Sh. Ajay Saxena

M/s. Nallesh Kumar Gupta.

Sh. S.K. Bhatia

20-05-2017.

20-06-2017

18 N / MM²

3 Nos.

15x15x15 cm.

R.M.C. M.15.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked RMC M.15 has/have been taken in my presence which represent 20cm quantity of works/supply made at site/store.

Signature of JE
in charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(OC)/AE(Lab.)/2017-18 /D-

Date:

Test No. 661

Date: 20.6.17

Date of Receipt: 20.6.17

Date of testing: 20.6.17

Concrete Mix: M-15

Days test: 28/31 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	7883	225	42.00	186.67	190.37	
2.	7942	225	42.50	188.89		
3.	8067	225	44.00	195.56		

EE May
Acceptable
Accordingly

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected & handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02

Copy to:-

1. EE/C-11

2.