

To

The Assistant Engineer(QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

JD-7836  
R-00-874  
RECEIVED 21 JUL 2017

**Part I**

Dispatch No. D-442/EE-C-5/DUSIB/2017 Date: 21-07-17  
Sub: Testing of CC cubes of mix M 20 for 7/28 days Compressive Strength.

A. L. No. AL-83/WH/ 4945/EE-C-5/DUSIB/ 2016-17 /D-1318 Dated. 08.02.2017

Name of work: EIUS

SH: -Providing and laying CC Pavement & repair of drains in JJC Bhanwar Singh Camp D-Block  
Vasant Vihar.

1. Details from where sample is collected	-----Site -----
2. Name of Circle/Division:	-----II/EE-C-5 -----
3. Name of Junior Engineer:	-----
4. Name of Assistant Engineer:	Sh. S.K. Mittal-----
5. Name of Executive Engineer:	Sh. S.K. Varshney-----
6. Name of Contractor/Agency:	M/s Devender Kumar Sharma -----
7. Name of Officer collecting sample:	AE/JE----- <u>S.K. Mittal</u> -----
8. Date of collection:	----- <u>21.07.17</u> -----
9. Date of testing:	----- <u>21.07.17</u> -----
10. Required strength:	----- <u>18 230</u> -----
11. No. of specimen sent for testing:	--3 Nos. -----
12. Size of specimen:	15 X 15 X15 cm-----
13. Mark of specimen:	----- <u>3</u> -----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/  
samples marked---3---has/have been taken in my presence which represent 20m<sup>3</sup> quantity  
of works/supply made at site/store.

Signature of J.E  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

**Part II****TEST REPORT**

No. SE(QC)/AE(Lab.)/2017-18/D- 1011

Date: 24/07/17

Test No. 874 Date: 21.7.17

Date of Receipt: 21.7.17

Date of testing: 21.7.17

Concrete Mix: M-20

Days test: 28/29 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8138	225	53.00	236.36	242.96	EE May Correlate Accordingly
2.	8256	225	56.00	248.89		
3.	8197	225	55.00	244.44		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and  
handed over by the field staff of the concerned division.

21/7/17  
Assistant Engineer (QC Lab.)  
DUSIB, Vikas Kutir, ITO

Copy to:-

1. EE/C-5  
2. oe