

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R-10: 0713

07 JUN 2019

Part IDispatch No. D-298/EEC/DUSIB

Sub: Testing of CC cubes of mix M-20 for 7/28 days Compressive Strength.

Date: 7/6/19

1. A. L. No. 14/WJ-6981/(81)/EE/C-6/DUSIB/2017-18/D-406 Dt.:02.06.2017
2. Name of work: E.I.U.S.
3. SH: Providing and laying cc pavement over main approach road remaining lanes and construction of drains at jj basti bilaspur camp, molarband (Project ID 000007841)
4. Details from where sample is collected From the Site of work
5. Name of Circle/Division Circle II/C-6
6. Name of Junior Engineer Sh. B N Singh
7. Name of Assistant Engineer Sh. O.P. Pruthi
8. Name of Executive Engineer M/S P.M Const. Co.
9. Name of Contractor/Agency Sh. B N Singh
10. Name of Officer collecting sample: 10.5.19
11. Date of collection: 07.6.19
12. Date of testing: As per CPWD Specification, ---250 Kg/sqm---
13. Required strength: --03--
14. No. of specimen sent for testing: 15 X 15 X 15 cm
15. Size of specimen: ---A---
16. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked---A-----has/have been taken in my presence which represent 30 m3 approx quantity of works/supply made at site/store.

Signature of AE
In charge of work 7/6/19

Signature of Contractor

Signature of Officer
taking sample (AE/EE) 7/6/19

Part IINo. SE(QC)/AE(Lab.)/2019-20/D- 990Test No. 0713 Date: 07/06/19Date of Receipt: 07.6.19Date of testing: 07.6.19Concrete Mix: M-20**TEST REPORT**Date: 7-6-19

S.No	Wt. of specimen in gms	Area in sq.cm	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8502 gm	2250	539	23.96	23.98 N/mm ²	EE May Correlate Accordingly
2.	8477 u	2250	544	24.18		
3.	8499 u	2250	536	23.82		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Copy to:-

1. EE/G-6
2. O/C

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-110002