

The Assistant Engineer-QC
Quality Control, DUSIB
Vikas Kutir, ITO, New Delhi

PNO-2055
RECEIVED 20 DEC 2017

Part I

Dispatch No AE-V/C-1/DUSIB/2017-18/D- 87

Date: 20/12/17

Sub: Testing of CC cubes of mix -----M-15----- for 7/28 days Compressive Strength.

A. L. No. WA/4222/AL-32/EE C-1/2016-17/D-1187

Dated: 21.01.2017

1. Name of Work: EIUS

Sub Head: P/L CC pavement and repairing/raising/reconstruction of drains at JJ Basti
Goyla Dairy (AC-34)(Project ID-7858)

2. Details from where sample is collected -----From Site-----
3. Name of Circle/Division: -----Circle-1/ C-1-----
4. Name of Junior Engineer: -----Mohit-----
5. Name of Assistant Engineer: -----V S Verma-----
6. Name of Executive Engineer: -----I K Srivastva-----
7. Name of Contractor/Agency: -----M/s J P Kapoor -----
8. Name of Officer collecting sample: -----V S Verma-----
9. Date of collection: -----21.11.2017-----
10. Date of testing: -----20.12.2017-----
11. Required strength: -----M-15-----
12. No. of specimen sent for testing: -----3-----
13. Size of specimen: -----15x15x15cm-----
14. Mark of specimen: -----J-----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked-----J-----has/have been taken in my presence which represent-----24.40-----quantity
of works/supply made at site/store.

Signature of JE/AE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(QC)/2017-18/D- 2390

Date: 22/12/17

Test No. 2055 Date: 20.12.17

Date of Receipt: 20/12/17

Date of testing: 20/12/17

Concrete Mix: M-15

Days test: 29 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8556 gm	225	41.50 T	184.44	184.44 legible	EE May Correlate Accordingly
2.	8398 "	225	40.10 T	177.78		
3.	8432 "	225	43.00 T	191.11		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and
handed over by the field staff of the concerned division.

COPY TO:-
1 EE/C-1

Assistant Engineer, QC
DUSIB, Vikas Kutir, ITO

Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi