

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

3777

R.No: 662 / 107869

31 AUG 2018

Part I

Dispatch No. D/EE/C-6/DUSIB/2018

Date: 26/8/18

Sub: Testing of CC cubes of mix M-25 for 7/28 days Compressive Strength.

A. L. No. J/WJ-6981/(160)/EE/C-6/AE-1/DUSIB/2017-18/D Dt: 9/2018

- 1. Name of work: Pay & Use JSC
SH: Upgradation of 30 seater conventional JSC at JH Basti Gandhi Camp behind F/V Market, Okhla (30 yr Maintenance)
- 2. Details from where sample is collected From the Site of work-----
- 3. Name of Circle/Division Circle II/C-6-----
- 4. Name of Junior Engineer -----
- 5. Name of Assistant Engineer Sh. R.S Rana-----
- 6. Name of Executive Engineer Sh. O.P. Pruthi -----
- 7. Name of Contractor/Agency M/s SNT Infratech Pvt. Ltd.-----
- 8. Name of Officer collecting sample: Sh. R.S Rana-----
- 9. Date of collection: 3-8-18
- 10. Date of testing: 31-8-18
- 11. Required strength: As per CPWD Specification, -----250 Kg/sqm-----
- 12. No. of specimen sent for testing: 03
- 13. Size of specimen: 15 X 15 X 15 cm-----
- 14. Mark of specimen: A

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked X has/have been taken in my presence which represent 30 m3 approx quantity of works/supply made at site/store.

Signature of AE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (AE/EE)

Part II

TEST REPORT

No. SE(QC/AE(Lab.)/2017-18/D- 773

Date: 03/08/18

Test No. 662 Date: 31.08.18

Date of Receipt: 31.8.18

Date of testing: 31.8.18

Concrete Mix: M-25

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg/sq.cm)	Remarks
			Load $\frac{kN}{Tonnes}$	Comp. strength (Kg/sq.cm) N/mm^2		
1.	8525 gm	22500	639 kN	28.40	28.73 N/mm^2	EE May Correlate Accordingly
2.	8518	22500	652	28.98		
3.	8484	22500	648	28.80		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Urban Shelter Improvement Board
Govt. of N.C.T., of Delhi
ITO, New Delhi-110002

Copy to:-

- 1. EE/C-6
- 2. 9c