

To,

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kutir, ITO, New Delhi

RNO-934
1 RECEIVED 28 JUL 2017

Part I

No. D-249 /AE-III/C-7/DUSIB/2016

Date: 19/7/17

Sub: Testing of Bricks/Bricks Tiles for Water Absorption/Efflorescence.

1. Name of work: -Pay & Use JSC

Sub Head: - Construction of 20 seater JSC at JJ cluster at Ashram Wala Bagh (Project ID 0000007941)

AcceptanceNo. W1/6031/82/PG/EEC-7/2016-17/D-1204

DATE:-30/12/2016

2 Detail from where sample is collected: AT SITE
3. Name of Circle/Division: C-7
4. Name of Junior Engineer Sh. TARUN GAUR
5. Name of Assistant Engineer: Sh. R.D. Passi
6. Name of Executive Engineer: Sh. K. B.Sharma
7. Name of Contractor/Agency: M/s-M.K.Traders
8. Name of Officer collection sample : Sh. R.D. Passi
9. Date of collection/Date of filling frog: 19/7/17
10. Date of Testing: 19/7/17
11. Identification Mark:
12. Class designation: 7.5
13. No. of specimen sent for testing: 10

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) markedCRB..... has/have been taken in my presence which representquantity of work/supply made at site/store.

Signature of JE
in-charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2016/D- 1174

Date : 16/08/17

Test No. 934 Date 28.7.17

Date of Receipt 28/7/2017

Date of Testing 28/7/2017

(A) WATER ABSORPTION

Day of Testing upto

S. No.	Dry Wt. (gms)	Wet Wt.(gms)	Water Absorbed (gms)	%age Absorbed	Average water absorption
1.	2525 gm	2862 gm	337 gm	13.35	13.18% ACCEPTABLE
2.	2490 "	2822 "	332 "	13.33	
3.	2712 "	3060 "	348 "	12.83	
4.	2666 "	2996 "	330 "	12.38	
5.	2640 "	3010 "	370 "	14.02	

(B) EFFLORESCENCE

Dt. of testing upto 16/8/2017

NIL / SLIGHT / MODERATE / HEAVY

ACCEPTABLE

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to:

1.

Assistant Engineer (QC) Lab.

DUSIB, Vikas Kutir, ITO

Delhi Urban Shelter Improvement Board

Govt. of N.C.T. of Delhi