

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

P.D:- 000008008

P.No. 2282

09 JAN 2018

Part IDispatch No. AE-VII/C-11/DUSIB/2018/D-181 Date: 8/1/18Sub: Testing of CC cubes of mix M-15 for 728 days Compressive Strength. (34 days)A. L. No. F1WC/4450/A1-18/EECH/DUSIB/2017-18/0-255 Date: 27-7-20171. Name of work:- E1451- P/L C.C. pavement on existing deteriorated
SH: C.C. pavement & 40 chain in JG Kalandan colony,
Bhalswa (Pocket C)2. Details from where sample is collected From CHC3. Name of Circle/Division C-4 C-114. Name of Junior Engineer M.K. MENGANI5. Name of Assistant Engineer M.K. GARG6. Name of Executive Engineer SH. AJAY7. Name of Contractor/Agency SH. NARESH KUMAR GUPTA8. Name of Officer collecting sample M.K. GARG9. Date of collection: 9/1/1810. Date of testing: 15/01/1811. Required strength: 03 NOS12. No. of specimen sent for testing: 15 cm x 15 cm x 15 cm13. Size of specimen: M-15

14. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked M.K. has/have been taken in my presence which represent 34 quantity of
works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)**Part II**No. SE(QC)/AE(Lab.)/2017-18/D-2549Test No. 2282 Date: 9.1.18Date of Receipt: 09/1/18Date of testing: 09/1/18Concrete Mix: M-15Date: 10/1/18Days test: 33 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8514 gm	225	39.07	173.33	180.00 kg/cm ²	EE May Correlate Accordingly
2.	8555 "	225	41.07	182.22		
3.	8616 "	225	41.507	184.44		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and
handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO

Copy to:-

1. EE/C-11

2.

Assistant Engineer (QC)
Nalhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-110022