

P.D:- 000000008

Rev 22/83

09 JAN 2018

To
The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

Part I

Dispatch No AE-VII/C-11/DUSIB/2018 D-181 Date: 8/1/18
Sub: Testing of CC cubes of mix M-15 for 728 days Compressive Strength. (30 days)

A. L. No. P.W.C. 14450/A1-18/EECH/DUSIB/2017-18/0-255 Date: 27.7.2017

- Name of work:- EUS:- P/L C.C. pavement over existing deteriorated SH: CC pavement & 40 chain in Jalandhar colony, Bhalawa (Pocket-C) From CHC
- Details from where sample is collected C-4 C-11
- Name of Circle/Division N.K. MENCHANI
- Name of Junior Engineer M.K. GARG
- Name of Assistant Engineer SH. AJAY
- Name of Executive Engineer SH. NARESH KUMAR GUPTA
- Name of Contractor/Agency M.K. GARG
- Name of Officer collecting sample 11/12/17
- Date of collection: 9/1/18
- Date of testing: 150 kg/cm²
- Required strength: 03 nos
- No. of specimen sent for testing: 15 mm x 15 mm x 15 cm
- Size of specimen: M-15
- Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked M-15 has/have been taken in my presence which represent 20 quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

No. SE(QC)/AE(Lab.)/2017-18 /D- 2550

Test No. 2283 Date: 9.1.18

Date of Receipt: 09/1/18

Date of testing: 09/1/18

Concrete Mix:

Days test: 29 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8404 gms	225	40.00 T	177.78	185.93 kg/cm ²	EE May Correlate Accordingly
2.	8480 "	225	42.50 T	188.89		
3.	8492 "	225	43.0 T	191.11		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO

Copy to:-

1. EE/C-11