To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kuteer, ITO, New Delhi

R.NO: 582
RECEIVED 09 JUN 2017.

Part I

Dispatch No AEI/CP/DUSIB/2017-18/D-75 Date: 9/6/17

Sub: Testing of CC cubes of mix M20 for 7/28 days Compressive Strength.

A. L. No. 76 LOA /E.E.C-9/DUSIB/2017-18/D- 667 *Dated:* 25-1-2017

Name of work:- EIUS: IMPROVEMENT of lanes by P/L CC Pavement and

Sub Head: Raising of drain and P/F M.S. grating on the crossing of drains in JJ BASTI Block 23-28 TRIL. Kpuri P.O.D 8071

1. Details from where sample is collected ------*from site*----------
2. Name of Circle/Division ----------*3 / C-9*----------
3. Name of Junior Engineer Sh. S.N Khurana
4. Name of Assistant Engineer Sh Mahinder Pal SHARMA
5. Name of Executive Engineer Sh. PHOOL Singh Ji
6. Name of Contractor/Agency M/S D.K Constn. Co
7. Name of Officer collecting sample Sh Mahinder Pal SHARMA
8. Date of collection: 6/5/17
9. Date of testing: 9/6/17
10. Required strength: ---*as per CPWD specifications*----------
11. No. of specimen sent for testing: ------*03 Nos.*----------
12. Size of specimen: -------*15cm X 15cm X 15cm*----------
13. Mark of specimen: (A)

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked ---(A)----has/have been taken in my presence which represent—*20 cum*--quantity of works/supply made at site/store.

Signature of AE In charge of work | Signature of Contractor | Signature of Officer taking sample (EE/AE)

Part II **TEST REPORT**

No. SE (QC)/AE (Lab.)/2017-18/D- Date:

Test No. 582 Date: 9.6.17

Date of Receipt: 9.6.17

Date of testing: 9.6.17

Concrete Mix: M-20 Days test: 28/34 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength Load (Tonnes)	Compressive Strength Comp. strength (Kg./sq.cm)	Average Strength (Kg./sq.cm)	Remarks
1.	8236	225	54.00	240.00	239.26	EE May Correlate Accordingly
2.	8198	225	52.00	231.11		
3.	8254	225	55.50	246.66		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

9/6/17

Assistant Engineer (QC-~~Lab~~)
Dusib, Vikas Kutir, ITO

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02

Copy to:-

1. EE/C-9