

To
The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

RECEIVED
Project I.D. - 000008091
03 JAN 2018
RNb. 2214

Part I
Dispatch No. D-17/EE/C/DUSIB/17-18 Date: 31/1/18
Sub: **Testing of CC cubes of mix M-20 for 7/28 days Compressive Strength.**

- A. L. No. 01/WJ-6981/(233)/EEC-6/AE-III DUSIB/2017-18/D-190 Dt.:27.04.2017
- Name of work: Environmental Improvement in Urban Slums.
SH: Providing and laying cc pavement over existing deteriorated lanes and construction of drain at JJ basti BIW camp.(Project ID 000008091)
 - Details from where sample is collected From the Site of work-----
 - Name of Circle/Division Circle II/C-6-----
 - Name of Junior Engineer -----
 - Name of Assistant Engineer Sh. B N Singh-----
 - Name of Executive Engineer Sh. O.P. Pruthi -----
 - Name of Contractor/Agency M/S P M Construction Company -----
 - Name of Officer collecting sample: Sh. B N Singh -----
 - Date of collection: -----
 - Date of testing: 6-12-2017-----
 - Required strength: As per CPWD Specification, 5-1-2018-----250 Kg/sqm-----
 - No. of specimen sent for testing: --03-----
 - Size of specimen: 15 X 15 X15 cm-----
 - Mark of specimen: ---A-----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked---A-----has/have been taken in my presence which represent 30 m3 approx quantity of works/supply made at site/store.

Signature of AE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (AE/EE)

Part II

No. SE(QC)/AE(Lab.)/2017-18/D-
Test No. 2214 Date: 3.1.18
Date of Receipt: 03/1/18
Date of testing: 03/1/18
Concrete Mix: M-20

TEST REPORT

2488

Date: 08/01/18

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8222gm	225	53.07	235.56	240.22 EE May Correlate Accordingly	
2.	8454 "	225	51.507	242.22		
3.	8496 "	225	55.07	244.44		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-92

Copy to:-

- EE/C-6
- o/c