

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R.No: 0602

RECEIVED 12 JUN 2017

Part I

Dispatch No. 2457/EEC-6-DUSIB/17-18 Date: 12/6/17
Sub: Testing of CC cubes of mix 1:2:4 for 7/28 days Compressive Strength.

P.I.D. 8214

A. L. No. 86/WJ-6981/(264)/EE/C-6/AE-II/DUSIB/2016-17/D-1616 Dt.:03.03.2017

1. Name of work: C/o of JSC (Pay & Use) SH:- Construction of 100 seater JSC at JJ Basti Sanjay Colony Y-Block at Plot No-Y-5 to Y-8 and back lane of Y-1 to Y-12 and ESS, Okhla Ind. Area Ph-II (Site II)
2. Details from where sample is collected From the Site of work- Label beam 2 slab
3. Name of Circle/Division Circle II/C-6
4. Name of Junior Engineer Sh. Kanwar Pal Singh Ramesh Khosla
5. Name of Assistant Engineer Sh. Amarnath
6. Name of Executive Engineer Sh. O.P. Pruthi
7. Name of Contractor/Agency Sh. Kanwar Pal Singh
8. Name of Officer collecting sample: Sh. Amarnath/Sh. O.P. Pruthi ✓
9. Date of collection: 12-5-17
10. Date of testing: 12-6-17
11. Required strength: As per CPWD Specification, 210 Kg/sqm
12. No. of specimen sent for testing: 03
13. Size of specimen: 15 X 15 X 15 cm
14. Mark of specimen: A-1

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked---A-1-----has/have been taken in my presence which represent 14 m3 approx quantity of works/supply made at site/store.

Amarnath
Signature of AE
In charge of work

Amarnath
Signature of Contractor

Amarnath
Signature of Officer
taking sample (AE/EE)

Part IITEST REPORT

No. SE(QC)/AE(Lab.)/2017-18/D-

Date:

Test No. 0602 Date: 12.6.17Date of Receipt: 12.6.17Date of testing: 12.6.17Concrete Mix: 1:2:4Days test: 28/31 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8235	225	51.00	226.67	223.70	EE may Correlate Accordingly
2.	8164	225	50.00	222.22		
3.	8127	225	50.00	222.22		

Amarnath
Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Amarnath
Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Held Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-66

Copy to:-

1. EE/C-6

o/c