

To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R.No:0598

RECEIVED 12 JUN 2017

Part I

Dispatch No D-452/EECZ/DURIB/17-18

Date: 12/6/17

Sub: Testing of Bricks/Brick tiles for Compressive Strength/Dimension.

- A. L. No. 85/WJ-6981/(137)/EE/C-6/AE-II/DUSIB/2016-17/D-1605 Dt.:03.03.2017
- Name of work: C/o of JSC (Pay & Use) SH:- Construction of 100 seater JSC at JJ Basti Sanjay Colony Y-Block at Plot No-Y-5 to Y-8 and back lane of Y-1 to Y-12 and ESS, Okhla Ind. Area Ph-II (I) (8219)
 - Details from where sample is collected From the Site of work-----
 - Name of Circle/Division Circle II/C-6-----
 - Name of Junior Engineer Sh. Ramesh Kumar-----
 - Name of Assistant Engineer Sh. Amarnath-----
 - Name of Executive Engineer Sh. O.P. Pruthi-----
 - Name of Contractor/Agency Sh. Prakash-----
 - Name of Officer collecting sample: Sh. Amarnath/Sh. O.P. Pruthi-----
 - Date of collection/Date of filling frog: 7-6-17/8-6-17-----
 - Date of testing: 12-6-17-----
 - Identification Mark: V.B.F-----
 - Class designation: 75-----
 - No. of specimen sent for testing: 15 Nos.-----
- Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked-V.B.F---has/have been taken in my presence which represent 32.500 quantity of works/supply made at site/store.

Signature of AE
Incharge of work

Signature of Contractor

Signature of Officer
taking sample (AE/EE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab.)/2017-18/D-

Date:

Test No. 0598 Date: 12-6-17

Date of Receipt: 12-6-17

Date of Testing: 12-6-17

(A) COMPRESSIVE STRENGTH

S. No	Dimensions			Maximum Strength. Failure (T)	Compressive Strength Failure (kg/sq.cm)	Av. Comp. Strength. Kg/sq.cm
	Length (cms)	Width (cms)	Area (sq.cm)			
1.	22.00 x	10.40	= 228.80	19.00	83.04	85.21 ACCEPTABLE
2.	21.50 x	10.60	= 227.90	18.00	78.98	
3.	21.60 x	10.60	= 228.96	20.00	87.35	
4.	22.00 x	10.60	= 233.20	20.00	85.76	
5.	22.00 x	11.00	= 242.00	22.00	90.90	

Tested in my presence

(B) DIMENSION TEST FOR 20 BRICKS

- Length : — NOT ASKED FOR —
- Width : —
- Height : —

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Copy to:-

- EE/C-6
- 0/C

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Gov. of N.C.T. of Delhi
JTC, New Delhi-02