

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

2894

RNo-2989

19 MAR 2018

Part I

Dispatch No D-197/AE-VIII/C-11/DUSIB/2017-18 Date: 16/3/2018

Sub: Testing of CC cubes of mix M-15 for 7/28 days Compressive Strength.

A. L. No. P.W.C.144501A/2017-18/DUSIB/2017-18/10/10-18 Date: 30-10-17

1. Name of work:- EXISTING C.C. ROVEROADS AND EXISTING DETERIORATED SH: C.C. ROVEROADS & G.P. DRAINAGE SYSTEMS SAMAJ KALYAN C.A.D. (KARIS) VANANGI, BUREL
2. Details from where sample is collected From site
3. Name of Circle/Division C-4 C-11
4. Name of Junior Engineer N.K. MENGHANI
5. Name of Assistant Engineer M.K. GARG
6. Name of Executive Engineer CH. AJAY
7. Name of Contractor/Agency M/s. Manoj G.M.H.
8. Name of Officer collecting sample M.K. GARG
9. Date of collection: 16-2-18
10. Date of testing: 16-3-2018
11. Required strength: 150 kg/cm²
12. No. of specimen sent for testing: 03 Nos
13. Size of specimen: 150mm x 150mm x 150mm
14. Mark of specimen: M.K.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked M.K. has/have been taken in my presence which represent quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (JE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2017-18 /D- 3343

Date: 20/3/18

Test No. 2989 Date: 19-3-18

Date of Receipt: 19/3/18

Date of testing: 19/3/18

Concrete Mix: M-15

Days test: 31 days

S. No	Wt. of specimen in gms	Area in sq.cm. mm ²	Compressive Strength		Average Strength (Kg./sq.cm) N/mm ²	Remarks
			Load (Tonnes) KN	Comp. strength (Kg./sq.cm) N/mm ²		
1.	8444 gm	22500	444	19.73	20.07 N/mm ²	May Correlate Accordingly
2.	8493 "	22500	452	20.09		
3.	8527 "	22500	459	20.40		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

[Signature]
Assistant Engineer (QC Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
3rd. of S.O.T. of Delhi
ITO, New Delhi-02

Copy to:-

1. EE/C-11
2. EE/C-11