

To

The Assistant Engineer(QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

R.No: 1427  
RECEIVED 18 SEP 2017

**Part I**

Dispatch No D.583/EE/C-5/DUSIB/2017

Sub: Testing of CC cubes of mix M 25 for 7/28 days Compressive Strength. Date: 18-09-17

A. L. No. AL-10/WH/4945/EE C-5/DUSIB/2017-18 /D- 130 dt. 16.05.2017

Name of work: Construction of BVK/C HALL

S. H. : Renovation of BVK (used as Community Hall) at JJ Basti Khizarbaba (Batla House)  
Okhla (AC-54). (PMS ID 8341)

1. Details from where sample is collected
2. Name of Circle/Division
3. Name of Junior Engineer
4. Name of Assistant Engineer
5. Name of Executive Engineer
6. Name of Contractor/Agency
7. Name of Officer collecting sample:
8. Date of collection:
9. Date of testing:
10. Required strength:
11. No. of specimen sent for testing:
12. Size of specimen:
13. Mark of specimen:

-----site-----  
-----Circle-II/C-5-----  
-----Sh. Suresh Kumar-----  
-----Sh. K.M. Goel-----  
-----Sh. S.K. Varshney-----  
-----Sh. Y.K. Goyal-----  
-----AE / JE-----  
-----21.8.17-----  
-----18.9.17-----  
-----M. W-----  
-----3 Nos.-----  
-----15 X 15 X 15 cm-----  
-----G-----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked G has/have been taken in my presence which represent 3000 quantity of works/supply made at site/store.

Signature of J.E  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

**Part II**

**TEST REPORT**

No. SE(QC)/AE(I.26.)2017 /D- 1662

Test No. 1427 Date:

Date: 18/09/17

Date of Receipt: 18/9/2017

Date of testing: 18/9/2017

Concrete Mix: M-25

M-25

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8336gm	225	65.507	291.11	287.41	EE May Correlate Accordingly
2.	8390 "	225	64.07	284.44		
3.	8408 "	225	64.507	286.67		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Copy to:-

1. EE/C-5
2. OK

Assistant Engineer (QC-Lab)  
DUSIB, Vikas Kutir, ITO  
Assistant Engineer (QC)  
Delhi Urban Shelter Improvement Board  
Govt. of N.C.T. of Delhi  
ITO, New Delhi-62