

To

The Assistant Engineer(QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

3456

R.No: 395

25 JUN 2018

**Part I**

Dispatch No. D-12/AE-III/C-11/DUSIB/2018 Date: 25-6-2018  
Sub: Testing of CC cubes of mix M-25 for 7/28 days Compressive Strength.

A. L. No. F/WC/4450/AD-45/EZC-11/DUSIB/2017-18/D-699 Date: 4/1/2018

1. Name of work:-

SH: built up facilities (BVK/Community Hall)  
Construction of community Hall at H-2 Block Jahangir Puri  
(P.O. - 8376)

2. Details from where sample is collected

From site:  
cessch-4/C-11

3. Name of Circle/Division

4. Name of Junior Engineer

5. Name of Assistant Engineer

6. Name of Executive Engineer

7. Name of Contractor/Agency

8. Name of Officer collecting sample

9. Date of collection:

10. Date of testing:

11. Required strength:

12. No. of specimen sent for testing:

13. Size of specimen:

14. Mark of specimen:

Mahender Singh  
Sh. Ajay Saxena  
M/s L.K. Builders and Suppliers  
Mahender Singh  
25/5/2018  
25/6/18 To 28/6/2018  
29 N/mm<sup>2</sup>  
3 Nos  
15x15x15 cm  
12-M-25

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/  
samples marked 12-M-25 has/have been taken in my presence which represent 14.00 cm quantity of  
works/supply made at site/store.

Signature of JE  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (JE/AE)

**Part II****TEST REPORT**No. SE(QC)/AE(Lab.)/2017-18/D- 450Date: 25/06/18Test No. 395 Date: 25/06/18Date of Receipt: 25/6/18Date of testing: 25/6/18

Concrete Mix:

M-25Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq. cm mm <sup>2</sup>	Compressive Strength		Average Strength (Kg./sq. cm) N/mm <sup>2</sup>	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq. cm) N/mm <sup>2</sup>		
1.	8510 gm	2250	673 kN	29.91	30.16 N/mm <sup>2</sup>	May Correlate Accordingly
2.	8466 "	2250	679 "	30.18		
3.	8493 "	2250	684 "	30.40		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and  
handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)  
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)  
Bali Urban Shelter Improvement Board  
Govt. of N.C.T. of Delhi  
ITO, New Delhi-02

Copy to:-

1. EE/En  
2. o/c