

To,

The Assistant Engineer (QC)  
Quality Control Lab, S & JJ, MCD  
Vikas Kutir, ITO, New Delhi

RNO. 707  
RECEIVED 28 JUN 2017

Part I

No. 12.61 A-217/07/017

Date: 27/6/17

Sub: Testing of CC cubes of mix M-25 for 7/28 days comp, strength

1. Name of work: - Improvement of SC/ST basties

Sub Head :-Construction of road by providing & laying RMC Pavement from MC primary school Sanagm park to A-Block Om nagar in sangam Park. ( Pid No.-000008393)

Acceptance No. WI/6031/12/PG/EE-C-7/2017-18/D-532

DATE:-09/05/2017

2. Detail from where sample is collected: Above noted work.
3. Name of Circle/Division: Circle-III, C-7
4. Name of Junior Engineer: Sh. Tarun gaur.....
5. Name of Assistant Engineer: Sh. R.D Passi.....
6. Name of Executive Engineer: Sh K.b. Sharma.....
7. Name of Contractor/Agency: M/S- Rakesh Kumar Goel.....
8. Name of Officer Collection sample: Sh. R.D Passi .....
9. Date of collection: 31/5/17
10. Date of Testing: 28/6/17
11. Required Strength: 28 N/MM<sup>2</sup>
12. No. of specimen sent for testing: 3 Nos.
13. Size of specimen: 15X15 Cms.
14. Mark of Specimen: Z

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked Z..... has/have been taken in my presence which represent 50% quantity of work/supply made at site/store.

Signature of JE  
In-charge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2017/D-0826

Date : 30/06/17

Test No. 707 Date 28.6.17

Date of Receipt : 28.6.17

Date of Testing : 28.6.17

Concrete Mix : M-25

Day test : 28 days

S. No.	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength Load (Tonnes)	Comp. strength (Kg./sq.cm)	Average Strength Kg/sq.cm	Remarks
1.	8238	225	62.00	275.56	287.41	EE May Correlate Accordingly
2.	8315	225	64.00	284.44		
3.	8364	225	68.00	302.22		

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to :

1. EE/C-7

o/c

Assistant Engineer (QC) Lab.

DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)

Delhi Urban Shelter Improvement Board

Govt. of N.C.T., of Delhi

ITC, New Delhi-02