

To,

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kutir, ITO, New Delhi

R No. 658
RECEIVED 19 JUN 2017

Part I

No. D-184/AE-III/C-7/DUSIB/2016

Date: 01/6/17

Sub: Testing of Bricks/Bricks Tiles for Water Absorption/Efflorescence.

1. Name of work: -Pay & Use Jsc

Sub Head :-Providing & laying Sewer line for 101 seater JSC at JJc Chowki No.4 GTK Road . (Pid No.-000008415)

AcceptanceNo.WI/6031/118/PG/EE-C-7/2016-17/D-254

DATE:-23/02/2017

- 2 Detail from where sample is collected: AT SITE
3. Name of Circle/Division: C-7
4. Name of Junior Engineer Sh. TARUN GAUR
5. Name of Assistant Engineer: Sh. R.D. Passi
6. Name of Executive Engineer: Sh. K. B.Sharma
7. Name of Contractor/Agency: M/s-J.S.Builders
8. Name of Officer collection sample : Sh. R.D. Passi
9. Date of collection/Date of filling frog: 16/6/17
10. Date of Testing: 16/6/17
11. Identification Mark: ABC
12. Class designation: 7.5
13. No. of specimen sent for testing: 10

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked ABC has/have been taken in my presence which represent 10.000 quantity of work/supply made at site/store.

Signature of JE
In-charge of work

Signature of Contractor

Signature of Officer taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2017/D-0943
Test No. 658 Date 19.6.17
Date of Receipt 19.6.17
Date of Testing 19.6.17

Date : 14/07/17

(A) WATER ABSORPTION

Day of Testing upto 22.6.17

S. No.	Dry Wt. (gms)	Wet Wt.(gms)	Water Absorbed (gms)	%age Absorbed	Average water	absorption
1.	2363	2703	340	14.39	15.06%	ACCEPTABLE
2.	2380	2728	348	14.62		
3.	2475	2843	368	14.87		
4.	2494	2892	398	15.96		
5.	2449	2828	379	15.47		

(B) EFFLORESCENCE

ACCEPTABLE

Dt. of testing upto: 10.7.17

NIL / SLIGHT / MODERATE / HEAVY

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to:

1. BE/C-7

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)
National Urban Shelter Improvement Board
Govt. of N.C.T., of Delhi
ITO, New Delhi-11002