To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

3237

RNo. 216
10 MAY 2018

Part I

Dispatch No EE/C-12/DUSIB/2017-18/D-381 Date: 8/5/18

Sub: Testing of CC cubes of mix for 28 days Compressive Strength. ~~(Bcc 1.7.5.3)~~

AL No. 58/WK/7205(148)/EEC-12/DUSIB/2016-17 /D- 216 dated 10.03.2017

Name of work: EIUS.

SH: Providing and laying CC pavement and construction of drains in Punjab Migrant Relief Camp/Basti at Peera Garhi, Rohtak Road (Project ID 000008443).

1	Details from where sample is collected	Block-D/C
2	Name of Circle/Division	Circle-4/C-12
3	Name of Junior Engineer	Sh Jashar
4	Name of Assistant Engineer	A.K. Sardana
5	Name of Executive Engineer	Sh. ~~K.K Sharma~~ Kamal Singh
6	Name of Contractor/Agency	M/S Hanuman Construction Co
7	Name of Officer collecting sample	A.K. Sardana
8	Date of collection:	12/4/2018
9	Date of testing:	10/5/2018
10	Required strength:	M-15
11	No. of specimen sent for testing:	03
12	Size of specimen:	15X15X15 cm
13	Mark of specimen:	

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked----------has/have been taken in my presence which represent---------quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (~~EE~~/AE)

Part II

TEST REPORT

No. SE(QC)/AE(~~Lab.~~)/2018-19/D-237 Date: 11/05/18

Test No. 216 Date: 10.5.18

Date of Receipt: 10/5/18

Date of testing: 10/5/18

Concrete Mix: M.15

Days test: 28 days

S. No	Wt. of specimen in gms	Area in ~~sq.cm.~~ mm²	Compressive Strength Load (~~Tonnes~~ KN)	Compressive Strength Comp. strength (~~Kg./sq.cm~~ N/mm²)	Average Strength (~~Kg./sq.cm~~ N/mm²)	Remarks
1.	8390 gm	22500	454 KN	20.18	20.10 N/mm²	EE May Correlation Accordingly
2.	8516 "	22500	444 "	19.73		
3.	8224	22500	459 "	20.40		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/~~samples~~ has/~~have~~ been collected and handed over by the field staff of the concerned division.

08/5/18
Assistant Engineer (QC-~~Lab~~)
DUSIB, Vikas Kutir, ITO

Copy to:-

1. EE/C-12