

P.D-000008474

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

PNQ. 1387
RECEIVED 15 SEP 2017

Part I

Dispatch No. AE/VI/C-11/DUSIB/2017/D-141 Date: 14/9/17
Sub: Testing of CC cubes of mix M-15 for 28 days Compressive Strength.

A. L. No. P-11NC144501A2-151EE-11/DUSIB/2017-10/10-215 Date: 14-09-2017

- Name of work: CON. of B.V.K. G. Hall
SH. Renovation, upgradation & special repair of existing B.V.K. in VC
-K-BIK ITI Janakpur
- Details from where sample is collected From site
- Name of Circle/Division C-4 CM
- Name of Junior Engineer M.K. MENONHANI
- Name of Assistant Engineer M.K. GARG
- Name of Executive Engineer SH. AJAY
- Name of Contractor/Agency SH. Narain Kumar Gupta
- Name of Officer collecting sample M.K. GARG
- Date of collection: 18/8/17
- Date of testing: 15/9/17
- Required strength: 150 kg/cm²
- No. of specimen sent for testing: 03 nos
- Size of specimen: 15cm x 15cm x 15cm
- Mark of specimen: M.K.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked M.K. has/have been taken in my presence which represent 25% quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (JE/AE)

Part II

TEST REPORT

No. SE(QC) AE(Lab.)/2017-18/D- 1630
Test No. 1387 Date: 15.9.17

Date: 18/09/17

Date of Receipt: 15/9/2017

Date of testing: 15/9/2017

Concrete Mix: M-15

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1	8292 gm	225	40.50 T	180.00	188.15 kg/cm ²	
2	8358 "	225	43.27	191.11		
3	8384 "	225	43.50 T	193.33		

**EE May
Correlate
Accordingly**

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITC, New Delhi-02

Copy to:-

1. EE/C-11

AC