

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

2NO-0104

10 APR 29 1968

Part II

Dispatch No D-47/EECZ/DUSIB/1B-19

Date: 19/4/12

Sub: Testing of rmc cubes of mix M-25 for 7/28 days Compressive Strength.

A. L. No. 34/EE/C-6/DUSIB/2017-18/D-696 Dt.: 10.08.2017

- | | | |
|-----|---|-----------------------------|
| 1. | Name of work: EIUS. | |
| 2. | SH: P/L RMC in deteriorated lanes & remodeling of drains in JJ Basti Janta Jeevan Camp, Tigr. | |
| 3. | Details from where sample is collected | From the Site of work----- |
| 4. | Name of Circle/Division | Circle II/C-6 ----- |
| 5. | Name of Junior Engineer | ----- |
| 6. | Name of Assistant Engineer | Sh. Deepak Kumar Behl----- |
| 7. | Name of Executive Engineer | Sh. O.P. Pruthi ----- |
| 8. | Name of Contractor/Agency | M/S Subhashwar Dayal |
| 9. | Name of Officer collecting sample: | Sh. Deepak Kumar Behl ----- |
| 10. | Date of collection: | 21/3/18 ----- |
| 11. | Date of testing: | 19/4/18 ----- |
| 12. | Required strength: | As per CPWD Specification, |
| 13. | No. of specimen sent for testing: | --03----- |
| 14. | Size of specimen: | 15 X 15 X15 cm----- |
| 15. | Mark of specimen: | ----- |

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked-----A-----has/have been taken in my presence which represent 30 m3 approx quantity of works/supply made at site/store.

Signature of AE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (AE/EE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2017-18 /D- 114

Date: 20/04/18

Test No. 0104 Date: 19.4.18

Date of Receipt: 19/4/11c

Date of testing: 19/4/18

Concrete Mix: 19/4/18 m-25

Days test: 29 days

S. No	Wt. of specimen in gms	Area in sq. cm. mm ²	Compressive Strength		Average Strength (Kg./sq. cm) N/mm ²	Remarks
			Load KN (Tonnes)	Comp. strength (Kg./sq. cm) N/mm ²		
1.	8660 gm	2250	680	30.22	29.92 N/mm ²	EE 110 Correlate According
2.	8555	2250	669	29.73		
3.	8533	2250	671	29.82		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO

Copy to:-

1. EE/c-6
2. o/c

Dr. H. B. Srinivasan
Jr., N.C.T. of Delhi
N.C. New Delhi-02