

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R. No 722
RECEIVED 03 JUL 2017

Part I

Dispatch No. D/331/EEC-5/DUSIB/2017

Sub: Testing of CC cubes of mix M 20 for 28 days Compressive Strength.

Date: 01/07/17

A. L. No. AL-95 /WH/ 4945/EE-C-5/DUSIB/ 2016-17 /D-1468 Dated. 14.03.2017

Name of work: EIUS

SH: -Providing and laying CC Pavement & remodelling of drains in JJ Basti Lal Gumbad Sadhna Enclave.

1. Details from where sample is collected
2. Name of Circle/Division:
3. Name of Junior Engineer:
4. Name of Assistant Engineer:
5. Name of Executive Engineer:
6. Name of Contractor/Agency:
7. Name of Officer collecting sample:
8. Date of collection:
9. Date of testing:
10. Required strength:
11. No. of specimen sent for testing:
12. Size of specimen:
13. Mark of specimen:

Site _____
II/EE-C-5 _____
Sh. Jitender Kumar _____
Sh. Raj Kumar Jindal _____
Sh. S.K. Varshney _____
M/s P.M. Const. Co. _____
AE/JE _____
5/6/2017
3/7/2017
200 kg/cm²
--3 Nos. _____
15 X 15 X 15 cm _____
F

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked F has/have been taken in my presence which represent 21.0% quantity of works/supply made at site/store.

Signature of J.E
In charge of work

Signature of Contractor

Signature of Officer
taking sample (AE/AE)

Part II

No. SE(QC)/AE(Lab.)/2017-18/D-

Test No. 722 Date: 3.7.17

Date of Receipt: 3.7.17

Date of testing: 3.7.17

Concrete Mix: M - 20

TEST REPORT

Date: 04/7/17

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8270	225	55.00	24444	242.22	EE May Correlate Accordingly
2.	8186	225	54.00	240.00		
3.	8223	225	54.56	24222		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
30th. n. S.C.T. of Delhi
ITC, New Delhi-02

Copy to:-

EE/C-5

ok