

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R.No 724
RECEIVED 03 JUL 2017

Part I

Dispatch No

D/331/EEC-5/DUSIB/2017

Date: 01-07-17

Sub: Testing of CC cubes of mix M 20 for 1/28 days Compressive Strength.

A. L. No. AL-95 /WH/ 4945/EE-C-5/DUSIB/ 2016-17 /D-1468 Dated. 14.03.2017

Name of work: EFUS

SH: -Providing and laying CC Pavement & remodelling of drains in JJ Basti Lal Gumbad Sadhna Enclave.

1. Details from where sample is collected
2. Name of Circle/Division:
3. Name of Junior Engineer:
4. Name of Assistant Engineer:
5. Name of Executive Engineer:
6. Name of Contractor/Agency:
7. Name of Officer collecting sample:
8. Date of collection:
9. Date of testing:
10. Required strength:
11. No. of specimen sent for testing:
12. Size of specimen:
13. Mark of specimen:

-----Site-----
-----II/EE-C-5-----
Sh. Jitender Kumar-----
Sh. Raj Kumar Jindal-----
Sh. S.K. Varshney-----
M/s P.M. Const. Co.-----
AE/IE-----
2/6/2017
3/7/2017
200 kg/cm²
-3 Nos.
15 X 15 X 15 cm
M

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked---M-----has/have been taken in my presence which represent 2/02 quantity of works/supply made at site/store.

Signature of J.E
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2017-18/D-

Test No. 724 Date: 3.7.17

Date of Receipt: 3.7.17

Date of testing: 3.7.17

Concrete Mix: M-20

Date: 04/07/17

Days test: 28/31 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	7947	225	55.00	244.44	238.52	EE May Correlate Accordingly
2.	7856	225	52.00	231.11		
3.	7913	225	54.00	240.00		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T., of Delhi
ITC, New Delhi-02

Copy to:-

1. BE/C-5
2. AE