

To,

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer, ITC, New Delhi

RNo 1098

RECEIVED 14 AUG 2017

Part I

No. D- 2561/A E.I.U. (C-7) 2017

Date: 11/8/17

Sub: Testing of Bricks/Bricks tiles for Dimension/Compressive Strength.

1. Name of work: -E.I.U.S

Sub Head: Improvement of drainage and providing CC Pavement in JJ Cluster
Mubarakbad Municipal ward No.72(Project ID 0000008587)

AcceptanceNo. WI/6031/25/PG/EEC-7/2017-18/D-862

DATE:-04/07/2017

- 2. Detail from where sample is collected: at site.
- 3. Name of Circle/Division: Circle-III, C-7
- 4. Name of Junior Engineer Sh. TARUN GAUR
- 5. Name of Assistant Engineer: Sh.R.D.PASSI
- 6. Name of Executive Engineer: Sh .K.B.SHARMA
- 7. Name of Contractor/Agency: M/s- Deepak Builders
- 8. Name of Officer collection sample : Sh. R.D.PASSI
- 9. Date of collection/Date of filling frog : 8/8/17 / 10/8/17
- 10. Date of Testing: 11/8/17
- 11. Identification Mark: AJIT
- 12. Class designation: 7.5
- 13. No. of specimen sent for testing: 05 Nos.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked has/have been taken in my presence which represent... 5.43... quantity of work/supply made at site/store.

Signature of JE
In-charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2017/D- 1276

Date : 16/08/17

Test No. 1098 Date

Date of Receipt 14/8/2017

Date of Testing 14/8/2017

S. No.	Dimensions			Maximum Strength Failure (T)	Compressive Strength failure (kg/sq.cm)	Average Compressive Strength kg/sq.cm
	Length (cms)	Width (cms)	Area (sq.cm)			
1.	22.90	11.50	263.35	23.00 T	87.34	84.50 kg/cm ²
2.	23.00	11.40	262.20	21.50 T	82.00	
3.	22.50	11.00	247.50	19.50 T	78.79	
4.	23.50	11.50	270.25	24.00 T	88.81	
5.	22.50	11.40	256.50	22.00 T	85.77	

DEMENSION TEST: FOR 20-BRICKS

- 1. Length :
- 2. Width :
- 3. Height :

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to:

- 1. E.E.C-7
- 2.

ole

Assistant Engineer (QC) Lab.

DUSIB, Vikas Kuteer, ITC

Delhi Urban Shelter Improvement Board

Govt. of N.C.T. of Delhi

ITC, New Delhi-02

ACCEPTABLE