3426

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

21 JUN 2018

Part I

Dispatch No 2701/EEC-6-DUSIB/18-19/30 Date: 20/6/18

Sub: Testing of CC cubes of mix M-20 for 7/28 days Compressive Strength.

A. L. No. 72/WJ-6981/(270)/EE/C-6/AE-V/DUSIB/2017-18/D-226 Dt.:17.02.2018

1. Name of work: EIUS.
   SH: Providing and laying CC pavement and repair of drain in JJ basti at Dora tambu.(ID- 8610)
2. Details from where sample is collected — From the Site of work----------
3. Name of Circle/Division — Circle II/C-6 ----------
4. Name of Junior Engineer — Sh. Ramesh Kumar----------
5. Name of Assistant Engineer — Sh. Deepak Kumar Behl ----------
6. Name of Executive Engineer — Sh. O.P. Pruthi ----------
7. Name of Contractor/Agency — Sh. Ravinder Kumar Gupta----------
8. Name of Officer collecting sample: — Sh. Deepak Kumar Behl ----------
9. Date of collection: — ----------22-5-18----------
10. Date of testing: — ----------21-6-18----------
11. Required strength: — As per CPWD Specification, -------250 Kg/sqm---------
12. No. of specimen sent for testing: — --03----------
13. Size of specimen: — 15 X 15 X15 cm----------
14. Mark of specimen: — ----A-3----------

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked------A-3----has/have been taken in my presence which represent 30 m3 approx quantity of works/supply made at site/store.

Signature of AE In charge of work | Signature of Contractor | Signature of Officer taking sample (AE/~~EE~~)

Part II **TEST REPORT**

No. SE(QC)/AE(Lab.)/2017-18/D- 430 Date: 25/06/18

Test No. 375 Date: 21/06/18

Date of Receipt: 21/6/18

Date of testing: 21/6/18

Concrete Mix: M-20 Days test: 30 days

S. No	Wt. of specimen in gms	Area in ~~sq.cm.~~ mm²	Compressive Strength: Load KN (~~Tonnes~~)	Compressive Strength: Comp. strength ~~(Kg/sq.cm)~~ N/mm²	Average Strength ~~(Kg/sq.cm)~~ N/mm²	Remarks
1.	8610 gm	22500	555	24.67	24.95 N/mm²	EE May Correlate Accordingly
2.	8566 "	22500	563	25.02		
3.	8550 "	22500	566	25.16		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/~~samples~~ has/~~have~~ been collected and handed over by the field staff of the concerned division.

21/6/18