

The Assistant Engineer-QC  
Quality Control, DUSIB  
Vikas Kutir, ITO, New Delhi

R.No/1874  
RECEIVED 28 NOV 2017

**Part I**

Dispatch No AE-V/C-1/DUSIB/2017-18/D- 78

Date: 28/11/17

Sub: Testing of CC cubes of mix -----M-25 ----- for 7/28 days Compressive Strength.

A. L. No. WA/4222/AL-49/EE C-1/2016-17/D-1276

Dated: 02.03.2017

1. Name of Work: National Urban Livelihood Mission(NULM)

Sub Head: Construction of Shelter for Urban Homeless at Sector-3, Ph-III, Dwarka (Project ID-8632)

2. Details from where sample is collected -----From Site-----  
3. Name of Circle/Division: -----Circle-1/ C-1-----  
4. Name of Junior Engineer: -----Mohit-----  
5. Name of Assistant Engineer: -----V S Verma-----  
6. Name of Executive Engineer: -----I K Srivastva-----  
7. Name of Contractor/Agency: -----M/s Pushpa Builders -----  
8. Name of Officer collecting sample: -----V S Verma-----  
9. Date of collection: -----31.10.2017-----  
10. Date of testing: -----28.11.2017-----  
11. Required strength: -----M-25-----  
12. No. of specimen sent for testing: -----3-----  
13. Size of specimen: -----15x15x15cm-----  
14. Mark of specimen: -----M-----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/  
samples marked-----M-----has/have been taken in my presence which represent-----cum quantity  
of works/supply made at site/store.

Signature of JE/AE  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

**Part II**

**TEST REPORT**

No. SE(QC)/AE(QC)/2017-18 /D- 2195

Date: 29/11/17

Test No. 1874

Date:

Date of Receipt: 28/11/17

Date of testing: 28/11/17

Concrete Mix: M-25

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8294 gm	225	61.27	271.11	280.74 kg/cm <sup>2</sup>	EE May Correlate Accordingly
2.	8414 v	225	64.27	284.44		
3.	8502	225	64.50 T	286.67		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and  
handed over by the field staff of the concerned division.

COPY TO:-

Assistant Engineer QC