

To

The Assistant Engineer(QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

2450

RNO 2607  
06 FEB 2018

**Part I**

Dispatch No

5-172/22-C-6/DUSIB/17-18

dt. 06/2/18

Date:

Sub: Testing of CC cubes of mix M-25 for 7/28 days Compressive Strength.

A. L. No. 45/EE/C-6/DUSIB/2017-18/D-877 Dt.:13.09.2017

1. Name of work: EIUS  
SH: Providing and laying CC pavement and improvement of drains in the deteriorated lanes of JJ basti Kharak Rewara (Remaining lanes). (ID- 8715)
2. Details from where sample is collected From the Site of work-----
3. Name of Circle/Division Circle II/C-6 -----
4. Name of Junior Engineer Bhupendra Kumar -----
5. Name of Assistant Engineer Sh. Lal Chand-----
6. Name of Executive Engineer Sh. O.P. Pruthi -----
7. Name of Contractor/Agency Sh. Subashwar Dayal
8. Name of Officer collecting sample: Sh. Lal Chand -----
9. Date of collection: 06/01/18 -----
10. Date of testing: 06/02/18 -----
11. Required strength: As per CPWD Specification, -----
12. No. of specimen sent for testing: --03-----
13. Size of specimen: 15 X 15 X15 cm-----
14. Mark of specimen: ---A-----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked-----A-----has/have been taken in my presence which represent m3 approx quantity of works/supply made at site/store.

Signature of AE  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (AE/EE)

**Part II**

**TEST REPORT**

No. SE(QC)/AE(Lab.)/2014-15 /D- 2900

Date: 07/02/18

Test No. 2607 Date: 6.2.18

Date of Receipt: 06/2/18

Date of testing: 06/2/18

Concrete Mix: M-25

Days test: 31 days

S. No	Wt. of specimen in gms	Area in sq.cm. mm <sup>2</sup>	Compressive Strength		Average Strength (Kg./sq.cm) N/mm <sup>2</sup>	Remarks
			Load KN (Tonnes)	Comp. strength (Kg./sq.cm) N/mm <sup>2</sup>		
1.	8470 gm	22500	670 KN	29.78	29.78 N/mm <sup>2</sup>	EE May Correlate Accordingly
2.	8493 "	22500	661 "	29.38		
3.	8528 "	22500	679 "	30.18		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)  
DUSIB, Vikas Kutir, ITO

Copy to:-

1. EBC-6