

To,

The Assistant Engineer (QC)
Quality Control Lab, S & JJ, MCD
Vikas Kutir, ITO, New Delhi

R.No: 796
RECEIVED 11 JUL 2017

Part I

No.

01221/ASE/11/C-7/2017-18

Date: 10/7/2017

Sub: Testing of CC cubes of mix M-15 for 7/28 days comp. strength

1. Name of work:-improvement of SC/ST basties
2. Sub-Head:- Construction of road by providing & laying RMC pavement for Dhobi Ghat Of SC/ST Basties Sangam Park
AC-18 Model town .(Project ID 000008780)
2. Detail from where sample is collected: Above noted work.
3. Name of Circle/Division: Circle-III, C-7
4. Name of Junior Engineer: Sh. Tarun gaur
5. Name of Assistant Engineer: Sh. R.D Passi
6. Name of Executive Engineer: Sh K.B. sharma.
7. Name of Contractor/Agency: m/s- Rakesh Kumar Goel
8. Name of Officer Collection sample: Sh.R.D .Passi.
9. Date of collection: 13/6/17
10. Date of Testing: 11/7/17
11. Required Strength:
12. No. of specimen sent for testing: 3 Nos.
13. Size of specimen: 15x15x15 Cms.
14. Mark of Specimen: D-15

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked D-15 has/have been taken in my presence which represent 125M³... quantity of work/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2016/D-0922
Test No. 796
Date of Receipt: 11.7.17
Date of Testing: 11.7.17
Concrete Mix: M-15

Date: 12/07/17

Day test: 28 days

S. No.	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength Kg/sq.cm	Remarks
			Load (Tonnes)	Comp.strength (Kg./sq.cm)		
1.	7982	225	39.50		175.56	184.45 EE May Correlate Accordingly
2.	8011	225	43.00		191.11	
3.	8023	225	42.00		186.67	

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to :

1. EE/C-7

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
301, N.C.T., of Delhi
ITC, New Delhi-02