2D!

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer. ITO, New Delhi

R No - 762
RECEIVED 06 JUL 2017

Part I
No.D-/4L/AE-III/C-2/DUSIB, ✓ mark Ganga ✓ Date. 05/07/2017

Sub: Testing of Bricks / ~~Bricks Tiles~~ for Water Absorption / Efflorescence

AL. No:- WF/4769/10/AE-III//EE-C-2/DUSIB/2016-17 /D- 116 Dated :26-05-2017

1. Name of work: DUSIB Estate Management Fund.

Sub Head: Constrction of boundary wall of UGR & parks,improvement of existing parks by raising wall etc and construction of new drains in 1168EWS flats at F,G,J & K Block Baprola Ph-II. (Basic Services)

2. Details from where sample is collected: From Site.
3. Name of Circle / Division: I/C-2
4. Name of Junior Engineer: Sh. Umesh Sharma
5. Name of Assistant Engineer: Sh. P.S.Johar
6. Name of Executive Engineer: Sh. S.C. Sharma
7. Name of Contractor / Agency: Sh. Ram Karan Goel
8. Name of Officer Collecting Sample: Sh. P.S.Johar
9. Date of collection / Date of filling frog: 29.07.17
10. Date of testing: 06.07.17
11. Identification Mark: GANGA
12. Class Designation: 7.5
13. No. of specimen sent for testing: 10 No.

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked ..Sign.....has / have been taken in my presence which represent ..50,000..... quantity of work / supply made at site / store.

Signature of J.E. **Signature of Contractor** **Signature of Officer Taking sample(EE / AE)**

Part II
No. SE(QC)/AE(Lab)/2017/D- 1065 Date. 28/07/17
Test No...762.....Date. 6.7.17.. Date of Receipt.....6.7.17.....
(A)WATER ABSORPTION Date of testing up to 11.7.17.....(11.7.17)

S. No.	Dry Weight (Grams)	Wet Weight (Grams)	Water Absorbed (Grams)	% age Water Absorbed	Average Water Absorption
1.	2780	3220	440	15.83	
2.	2941	3419	478	1625	
3.	2816	3266	450	15.98	15.887
4.	2857	3297	440	15.40	
5.	2932	3397	465	15.86	

ACCEPTABLE

(B) EFFLORESCENCE Slight ACCEPTABLE Date of testing upto..26/7/2017..

Efflorescence ~~found:~~ Nil / Slight / ~~Moderate /~~ Heavy

Only testing has been conducted in this laboratory, the sample have been collected, cured and handed over by the field staff of the division.

COPY TO:-
1- EE/C-2
2.
dlc

Assistant Engineer(QC) ~~Lab.~~
DUSIB, Vikas Kuteer, ITO.
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi